

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
96879	12/26/00	AC	Need pilot lights in cans turned on
96882	12/26/00	AC	No heat in spaces utilized by the frag in bldg 1665. Thermostat says temp is 56 degrees.
96884	12/26/00	AC	Current temp is 60
96886	12/26/00	AC	No heat NA, NBNC, ND store
96897	12/26/00	AC	Heater, rear door by paint shop, bldg 1798, runs cold/hot. On P&P side, heater is leaking.
96906	12/27/00	AC	Please relight and check heaters in can 1355 and can 1380 thank you
96909	12/27/00	AC	No heat
96918	12/27/00	AC	The heating unit in the back of bldg 1798 has a small crack in one of the steam pipe that leads into the heating unit. It is leaking steam and water. Repair as soon as possible.
96928	12/27/00	AC	No steam in shop 94401, bldg 137
96929	12/27/00	AC	No steam in ramp extension to machine shop, back of bldg 137. Urgent!
96936	12/27/00	AC	Check out heat in bldg 163
96938	12/27/00	AC	Heat inoperable in 4 & 5 test cell.
96944	12/27/00	AC	The temperature in our office is 80 degrees F. We need some relief before we overheat! Thanks
96962	12/27/00	AC	Shop 94405 to hot
96968	12/27/00	AC	Temp too hot in 4.8.75 please turn down
96973	12/27/00	AC	Water leak at overhead heater in H-53 hanger at post #08, overhead the door going into the small surface paint, it is getting worse too
96974	12/27/00	AC	Hot on Mezzanine C bldg 137
96978	12/27/00	AC	Check out heat in the bldg 159
96997	12/28/00	AC	I don't know what to put this under, but the air vents and air returns overhead need to be cleaned. We are located on Mezzanine C
97006	12/28/00	Vents	Exhaust vent in the P3 rubber room is inoperable. Safety hazard due to hazardous chemical fumes used in the room.
97012	12/28/00	AC	We have absolutely no heat! Please fix.
97023	12/28/00	AC	Fuel heater on test stand is operational but thermostat must be set much higher then required temp calibration personal say there is a mechanical problem (this is not a work stoppage)
97029	12/28/00	AC	We have absolutely no heat! Please fix. Mezzanine B.
97031	12/28/00	AC	Need pilot lights on heaters lit.
97038	12/28/00	Vents	Need vent fan (#V2) closed (rubber room) this is a temp control area will need a lift to reach the fan.
97041	12/28/00	AC	Temp in shop area excessively warm. 12-28 at 1355.
97045	12/28/00	AC	Mezzanine B bldg 137 - check computer data for heat for shop 94401 and telephone office. Computer based program
97053	12/28/00	AC	T2 problem on old #1 T-58 test stand.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
97060	12/29/00	AC	Please light heater in can1355 and cap the exhaust fans thank you
97062	12/29/00	AC	Right half of bldg has very little heat. About 60
97063	12/29/00	Vents	Exhaust vent in the P3 rubber room is inoperable. Safety hazard due to hazardous chemical fumes used in the room.
97064	12/29/00	Vents	Need vent fan (#V2) closed (rubber room) this is a temp control area will need a lift to reach the fan.
97079	12/29/00	AC	Relocate modine heater that is presently located over chiller in front of bldg 133
97080	12/29/00	AC	Fluid heater is inoperable. Thank you
97082	12/29/00	AC	Heat in paint shop is not working every good, can you please have some one look at it almost a work stoppage. Thank you
97083	12/29/00	AC	Perform PM as per instructions
97086	12/29/00	AC	Repair Mezzanine B controls, work stoppage
97092	12/29/00	Vents	Repair vent on D-24 per IH survey
97096	12/29/00	AC	Retrofit the CIT test stand as per instructions
97100	12/29/00	AC	Heat kicks on but only stays on for a few seconds. Temp will not rise. Office is very cold.
97102	12/29/00	AC	Heat kicks on but only stays on for a few seconds. Temp will not rise. Office is very cold.
97113	12/29/00	AC	Heat in paint shop is not working very good, can you please have some one look at it almost a work stoppage. Thank you
97118	12/29/00	AC	Ice machine evaporator pump is not emptying the water catch pan and it is overflowing and running onto the floor.
97144	1/2/01	AC	No heat.
97150	1/2/01	AC	No heat in the paint storage room, needs attention ASAP
97151	1/2/01	AC	No heat, blows cold air. Current temperature in bldg 59 degrees.
97152	1/2/01	AC	Heat is off all over shop area, employee about to freeze to death please help thanks.
97156	1/2/01	AC	Overhead heater leaking in prep side of hanger.
97158	1/2/01	AC	Due to the large amount of hazmat, I am not allowed to run a floor heater within this room. This room needs climate control for the operator working and for the material stored within the room.
97159	1/2/01	AC	Buff and grind room is down work stoppage needs help thanks.
97164	1/2/01	AC	Heater on prep side not working water coming out and no heat in hallway by elevator
97167	1/2/01	AC	No heat in graphic arts area
97170	1/2/01	AC	Heat not working in new maintenance addition upstairs. Warranty item!!
97173	1/2/01	AC	No heat in graphic arts area
97182	1/2/01	AC	Hot in controller office ok in the 600 office
97191	1/2/01	AC	No heat in shop
97193	1/2/01	AC	T2 refrigeration problem

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
97194	1/2/01	AC	No steam coming to bldg has Johnson Controls opened controls?
97197	1/2/01	AC	Main heater is inoperable. Please fix it as soon as possible.
97198	1/2/01	AC	Alarm on AC in H-60 avionics ISPAC lab was going off. Red failure lights indicated "no air flow". Unit not functioning at all. Turned unit off.
97203	1/2/01	Vents	Exhaust fans will not operate in mixing room. Keeps kicking off breaker. Safety hazard. Need repair ASAP.
97216	1/2/01	AC	Repair window unit as per instruction
97217	1/2/01	AC	Cold in shop area and extremely cold in shop office, repair as required!
97218	1/2/01	AC	The overhead AC have leaked condensate. The temperature in the labs is a little high. The overhead and under floor systems appear to be un-balanced. Request assistance to determine optimum operating conditions. Check out Liebert under floor
97220	1/2/01	AC	Repair AC as per instructions, check daily Mezzanine G computer room
97224	1/2/01	AC	Cold in shop area and extremely cold in shop office, repair as required!
97226	1/2/01	AC	The contractors, that came into bldg 1798 this morning to fix the heating unit, needs to come back again because the same heating unit is still leaking and it's leaking water all over the floor.
97232	1/2/01	AC	Repair AC chillers as per instructions
97235	1/2/01	AC	Repair chiller 1
97245	1/2/01	AC	No heat
97250	1/2/01	AC	One of the heaters has a leak, and will not heat.
97255	1/2/01	AC	Need someone to come and light the pilot on these heaters. We have not heat. Thank you.
97262	1/2/01	AC	Sorry to keep bothering you about the heat/air problem in the drawing files! But - our heat unit is blowing out "cold air"? Thanks
97264	1/2/01	AC	Heating unit air compressor is unserviceable no heat
97272	1/2/01	AC	Check the small pig cooker at 1798
97279	1/2/01	AC	T2 system down T64 test stand. Thanks.
97293	1/3/01	AC	No heat in bldg again, currently 58 degrees in bldg
97294	1/3/01	AC	The outside unit of the #4 Mitsubishi overhead AC in room 107 was making a loud humming sound, hot, fan not running. Secured unit. Temp in labs=77. Hi temp will lead to work stoppage/damage to equipment
97296	1/3/01	AC	Heater is not working in the blast area of the plating shop
97297	1/3/01	AC	No heat in lobby
97299	1/3/01	AC	Please send someone to bldg 1798 ASAP. We have a serious leak with the heating unit that was worked on yesterday morning. Now it leaking steam and water worse than before. Please send someone down here to shut off the valve.
97317	1/3/01	AC	Disconnect heat and water from Metco heat exchanger

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
97318	1/3/01	Vents	Put in request yesterday (ticket no. 97203) to repair exhaust fans in mixing room. It was kicking off breakers. Individual came in and replace a heat fuse and found out that motor is bad. This is a work stoppage situation. What is being done?
97326	1/3/01	AC	Please put some heat in the break room of this bldg
97350	1/3/01	AC	In the office upstairs when you want heat, AC comes on and off. Please check out and explain to the supervisor how the system works. Thanks
97356	1/3/01	AC	Repair AC as per instructions
97358	1/3/01	AC	Disconnect heat and water from Metco heat exchanger
97366	1/3/01	AC	Heater on prep side not working water coming out and no heat in hallway by elevator
97383	1/3/01	AC	We have no heat in break room or locker room.
97389	1/4/01	AC	Yes we have no heat! Frozen in time. Please help.
97398	1/4/01	AC	The chiller for our anodize tank is down. This is a work stoppage. Thanks
97400	1/4/01	AC	Repair controller on the heat in the penthouses
97403	1/4/01	AC	Repair pump and chiller
97406	1/4/01	AC	Still awaiting someone to fix heat in shop and shop office.
97409	1/4/01	AC	Repair check pig cookers in the paint shop
97414	1/4/01	AC	Relocate register as per instructions
97417	1/4/01	AC	Repair 3 each fan motors as per instructions
97426	1/4/01	AC	Graphic arts has no heat
97427	1/4/01	AC	Small heater in masking room of paint shop (bldg 1798) needs repair.
97437	1/4/01	AC	Check all of the propane tents as per my instructions
97441	1/4/01	AC	Cold air blowing from vents. Current temperature in shop is 60 degrees.
97442	1/4/01	AC	Urgent request to have someone look at the heat in shop cannot paint without it. See for more info. Inside the shop.
97452	1/4/01	AC	Heat source is not working properly. Very cold in the office.
97458	1/4/01	AC	Graphic arts has no heat
97464	1/4/01	AC	AC pumping water into bldg
97475	1/4/01	AC	Ceiling heater above pc area is leaking and causing problems. Slip hazard, possible electrical hazard. See PC station 19.
97481	1/4/01	AC	Cool air coming down from heat vent. Please come check. It's pretty cool in here.
97496	1/4/01	AC	Repair heat in the paint shop
97498	1/4/01	AC	Condo third floor cold in the 46 hanger
97499	1/4/01	AC	Repair AC as per instructions

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
97511	1/4/01	AC	My office will not get warm.
97517	1/4/01	AC	Stripping barn has three air handler units. One not working at all (center one), other two have steam going to coils, but not enough hot air. Check out
97527	1/4/01	Vents	Black residue coming out of vents over desk. Person is located in room 577.
97547	1/5/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder
97552	1/5/01	Vents	Black residue coming out of vents over desk. Person is located in room 577.
97554	1/5/01	AC	Old computer room is very humid
97561	1/5/01	AC	Heater not working properly, possibly need the lines drained to all heater in ramp bldg
97563	1/5/01	AC	Air dampeners for make up air are stuck open and air is pouring in from outside making working in this area unacceptable see for info.
97564	1/5/01	AC	ASE 5 will not reach max temperature. The most it will go up to is 138 degrees, we need to reach 145 degrees. This is a work stop.
97570	1/5/01	AC	ASE 5 will not reach max hot temp, will only reach 138 degrees need 145 degrees. Work stop.
97594	1/5/01	AC	No heat in break area in PMB barn.
97599	1/5/01	AC	Heating unit is unserviceable no heat please help. Thanks
97610	1/5/01	AC	No heat in paint area
97612	1/5/01	AC	Heater #82 is inoperable
97614	1/5/01	AC	Block off air intake to McQuay HVAC unit on roof that services E&E area. Install charcoal prefilter on intake airside to remove odors coming from exhaust stack of hydrogen furnace.
97618	1/5/01	AC	Heating unit is unserviceable no heat please help. Thanks
97619	1/5/01	AC	ASE 5 will not reach max temperature. The most it will go up to is 138 degrees, we need to reach 145 degrees. This is a work stop.
97621	1/5/01	AC	The heating coils in the penthouse on the roof has a leak. This water is running down on some of our equipment. This needs to be fixed ASAP. Thanks
97635	1/5/01	AC	No heat in paint area
97637	1/5/01	AC	Block off air intake to McQuay HVAC unit on roof that services E&E area. Install charcoal prefilter on intake airside to remove odors coming from exhaust stack of hydrogen furnace.
97642	1/5/01	AC	Heating unit not functioning
97643	1/5/01	AC	AC on Mezzanine 19-2, one side hot other side cold
97645	1/5/01	AC	Too hot in budget/accounting office.
97647	1/5/01	AC	No heat at Mezzanine C
97711	1/6/01	Cooling Tower	Please unstop drain on T-58 water tower.
97720	1/7/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
97755	1/8/01	AC	Humidity levels in clam shelter cs1 at runway 28 are slightly out of tolerance on high side. Need humidistat adjusted to correct. Use 7f5kc55.
97756	1/8/01	AC	Need temp checked in shop area.
97785	1/8/01	AC	Room AC/heating system is not working. Is located in a room with technical equipment (scanning electron microscope).
97791	1/8/01	AC	Heating unit does not work any heat since Thursday, Jan 4. Please help
97792	1/8/01	AC	Heating unit does not work. No heat since Thursday Jan 4. Please help thanks
97798	1/8/01	AC	The heat in the front of the bldg is unbearable. Needs to be checked. Hot air is blowing out of the vents.
97802	1/8/01	AC	We asked for heat and we got it! Not wanting to be a nag but it is 80 degrees in shop. Can we adjust to a more moderate range?
97811	1/8/01	AC	We asked for heat and we got it! Not wanting to be a nag but it is 80 degrees in shop. Can we adjust to a more moderate range?
97823	1/8/01	AC	Request maintenance of heater in 1st floor southeast (cass wing). Temp in the morning is 62-66 & doesn't rise above 70 during the day. Ducts seem to be pushing out cold air rather than warm. Coats are worn in workspaces. Hands & feet are cold all day.
97839	1/8/01	AC	Heat in 944401 and 944402 is unbearable. See ticket 97756.
97851	1/8/01	AC	Stand not going to -65. Work stop (cit stand)
97883	1/9/01	AC	ASE #2&4 are having T2 air problems you need to check the air dryer
97904	1/9/01	AC	Clean condenser coil inside and out. Discrepancy found during PM on link #V465865
97930	1/9/01	AC	Heat in 944401 and 944402 is unbearable. See ticket 97756. Condensing unit is not running. When TAC turned the condenser on there was a lot of noise in the condenser. Possibly there is no freon in the unit.
97932	1/9/01	AC	AC problem in clean room. Humidity is 47% - temp 74 degrees should be 62 degrees
97940	1/9/01	AC	AC problem in clean room. Humidity is 47% - temp 74 degrees should be 62 degrees
97949	1/9/01	AC	Remove window AC in hanger H53 to clean coils.
97954	1/9/01	AC	No heat to include office
97961	1/9/01	AC	Have been without heat since Thursday, Jan 4. Please repair heat or send cold medicine or cold weather gear. I am old and feeble. Thanks
97969	1/9/01	AC	Have been without heat since Thursday, Jan 4. Please repair heat or send cold medicine or cold weather gear. I am old and feeble. Thanks
97978	1/9/01	AC	Heater in bldg 4172, shop area not working properly, fan works, no heat. Extremely cold
97984	1/9/01	AC	Assist in troubleshooting 250T chilled water system in bldg 133 accessories test.
97986	1/9/01	AC	Heating unit not functioning

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
97993	1/9/01	AC	VIPs from NAVAIR coming tomorrow to see ASE T64 and T2 will not function due to air problems
98016	1/10/01	AC	Temperature in computer labs 107 and 112 is extremely high. Computers have shut down. This is a work stoppage!
98017	1/10/01	Vents	Ventilation system in soldering trailer 8 not working properly
98021	1/10/01	AC	No heat in bldg blows cold air.
98022	1/10/01	AC	Heat is not working in ordnance shop
98026	1/10/01	AC	Check temp in computer room, it's too hot
98027	1/10/01	Vents	Replace vents in 654.
98035	1/10/01	AC	No heat in old paint hanger 4 heater not working. Hangar must be heated to ensure proper adhesion of paint to aircraft.
98036	1/10/01	AC	We have cold air coming down from the heat vent. Please come check. It's kinda hard to use a computer with gloves on. Help!!!
98049	1/10/01	AC	Repair chiller in bldg 4225 as required. Surging problem with the compressor. Also need to install new E-prom kit.
98066	1/10/01	AC	Clean room temp is way to high needs attention ASAP. Called yesterday no one came. Called this morning. Still no response.
98078	1/10/01	AC	Heat is not working in ordnance shop
98096	1/10/01	AC	Heater in old paint hanger leaking hot water
98129	1/11/01	AC	Heaters are leaking.
98146	1/11/01	AC	Refrigerator in instrument shop needs a charge
98152	1/11/01	Vents	Vents in soldering trailer #8 still not working properly - after it runs approx 10 minutes performance drops off significantly
98173	1/11/01	AC	Window AC iced over
98176	1/11/01	AC	Computer room has an alarm going off (high temp)
98185	1/11/01	AC	Need to check thermostat for AC in 930/950 SBU for proper operation. And if found to be ok, a lockout box needs to be placed over it.
98294	1/12/01	Vents	Exhaust vent had filter now does not. Please check it out and repair as necessary. Thanks
98303	1/12/01	AC	Control system up top is closed needs to work sent to TAC
98305	1/12/01	AC	Heating unit not working
98307	1/12/01	AC	Heating unit not working
98312	1/12/01	AC	Temp is 80 needs to be adjusted
98337	1/12/01	AC	Two old thermostats are missing covers. The either need to be repaired or removed (if not operational).
98345	1/12/01	AC	Air handler on the roof has a squealing belt; we can smell rubber through the ductwork. Needs repair ASAP. Thanks
98361	1/12/01	AC	Please open vents so heat is evenly distributed in shop area. Vents are on ceiling in P3 rubber room
98396	1/14/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
98398	1/15/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
98400	1/16/01	AC	Cold, heat set on 70, AC set on 75. Temp is 60, blue light is on and cold air is blowing. Lock box put on 1/11pm and set. I don't know what is wrong but it has been on going please get someone to fix. ASAP.
98411	1/16/01	AC	960-division office and action center, Mezzanine B, & D, bldg 133 AC not working properly. Feels like an oven up there today. We need it fixed ASAP today. Thanks.
98415	1/16/01	AC	137 Mezzanine C too cold
98418	1/16/01	AC	Too hot in the office
98419	1/16/01	AC	Top of B-245 air handler #1 busted condensate pipe - hole in steam pipe valves V-1 & V-6 secured
98446	1/16/01	AC	80 degrees and rising!
98453	1/16/01	AC	MO display on thermostat. Thermostat not working.
98454	1/16/01	AC	80 degrees and rising!
98458	1/16/01	AC	Temp in the division office is 80 F. The thermostat is set at 74 F. EMS computer shows the supply fan running and sup air temp 70.4. Room temp 1 shows ZN-T 81.2 F, and room 3 ZN-T 74.5 F. This problem is continuous. Check previous tickets.
98475	1/16/01	AC	No control for the temperature in the paint storage mixing room one time it's too cold now it's too hot. Needs a thermostat in the paint storage area.
98514	1/16/01	AC	Tank #105 is overheating, temperature is suppose to be to be 140, now at 155
98516	1/16/01	AC	Discrepancy discovered during PM on link #V517899. Steam coil has a bad leak.
98519	1/16/01	AC	2nd request: 82 degrees and rising! Could you at least let me know what is happening so I can inform the employees. The first ticket maintenance status is reissued. What does that mean? Thank you
98559	1/17/01	AC	Heater fan blades hitting cage. Top of station 5.
98562	1/17/01	AC	Heater fan blades hitting cage top of station 5
98667	1/17/01	Vents	The exhaust vent has fallen out of the ceiling in the wash down room. The room is in the 95665/95447 shop area.
98697	1/17/01	AC	Alarm on air handling unit keeps going off.
98713	1/17/01	Vents	Exhaust vent E4, XO1664, either has a bad pulley or belts are loose, emitting a loud noise while in operation. Located in old paint hanger, flight line side.
98732	1/18/01	AC	Stand will not go down to -25 degrees can only reach -16. Needs a freon boost
98734	1/18/01	AC	Laboratory testing conditions being affected by excessive heat. Most notably affecting front laboratory area. Heater seems to be blowing full blast. Yesterday, temperature reached 83 degrees F. Needs fixed ASAP or work stoppage will result.
98735	1/18/01	Vents	Exhaust vent E4, XO1664, either has a bad pulley or belts are loose, emitting a loud noise while in operation. Located in old paint hanger, flight line side.



Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
98751	1/18/01	AC	Chiller for the hard anodize process is down. Work stoppage. Thanks
98753	1/18/01	AC	Has been handling this "problem" here.
98791	1/18/01	AC	AC is not working. Thermostat is set to 60 for cooling, but temperature is 80
98868	1/18/01	AC	Ice maker in back aisle by heat treat section needs filter changed... Ice tastes real baddddd! It is a tall filter, whole house type. Thanks
98871	1/18/01	AC	Check oil level in Trane compressors and record readings each shift. 6.3.658
98906	1/19/01	AC	Please check bldg 1665 to see why there is no hot water in restrooms. Previous ticket sent/closed out. Still no hot water. Urgent!!
98909	1/19/01	AC	AC on Mezzanine C, repair as needed
98914	1/19/01	AC	AC unit 2 making all kinds of noise when compressor comes on. The telephone office is a temperature sensitive area.
98929	1/19/01	AC	AC for the RCA room pump area not cooling the room sufficiently.
98956	1/19/01	AC	AC won't work in office
98969	1/19/01	AC	Replace door seal on AC found during PM.
98984	1/19/01	AC	AC will not come on. The outside unit is making a loud noise.
98989	1/19/01	AC	AC unit #2 in hot air test channel area leaking water on floor creating slip hazard.
99025	1/22/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
99026	1/22/01	AC	Not getting chill water to ASE test stands / work stop
99032	1/22/01	AC	Repair heat in small clean & blast area.
99033	1/22/01	AC	AC will not come on. The outside unit is making a loud noise.
99034	1/22/01	AC	Request immediate maintenance of heating unit for southeast wing (cass-ipt) of bldg 200. Current temperature as of 6:30 this am 62 degrees. Thank you.
99035	1/22/01	AC	AC unit #2 in hot air test channel area leaking water on floor creating slip hazard.
99042	1/22/01	AC	Not getting chill water to ASE test stands / work stop
99052	1/22/01	AC	Rubber shop has no heat
99073	1/22/01	AC	HVAC unit leaking above the edm drill. Shop slip hazard. Please expedite!
99079	1/22/01	AC	No heat 2nd floor. (AV8bate)
99081	1/22/01	AC	Heat in shop not working.
99088	1/22/01	AC	New coils were put in last week in the heater for the rotor head paint shop and the heater seemed to be working Friday a much warmer day. But today it is just blowing out cold air.
99089	1/22/01	AC	Test stand will not go to -25 work stop
99092	1/22/01	AC	We have cold air blowing down from the vents. We have no heat. Please come check. We think the steam is turned off.

Ticket Number	Date	Problem Type	Description
99095	1/22/01	AC	Heat pump located behind shop is not working properly. AC will not work at all. Heat aux. light comes on most of the time and stays on continuously. Problem seems to be worse after new thermostat was installed a few weeks ago.
99105	1/22/01	AC	#22302 air handler on roof needs repair (steam). Never repaired by mechworks.
99110	1/22/01	AC	Repair air dryer as per instructions
99121	1/22/01	AC	Heat pump located behind shop is not working properly. AC will not work at all. Heat aux. light comes on most of the time and stays on continuously. Problem seems to be worse after new thermostat was installed a few weeks ago.
99134	1/22/01	AC	Please adjust temperature in shop. Currently too hot!
99137	1/22/01	AC	Heat in shop not working.
99163	1/22/01	AC	Fuel control test stand needs freon. Work stoppage.
99164	1/22/01	AC	The AC on the wotan controller is making a loud noise
99180	1/23/01	AC	Heater not working (no steam) between columns N9 and P9 in the 53 hanger. Just blow cold air.
99192	1/23/01	AC	Repair AC water everywhere, Mezzanine G 137
99194	1/23/01	AC	Test stand won't get cold enough. Work stop
99204	1/23/01	AC	Test stand won't get cold enough. Work stop
99219	1/23/01	AC	No heat in offices in bldg 1665. None in our office, F-4; C-130 office in hanger.
99248	1/23/01	AC	Please check HVAC system. Temp has risen to 80 degrees in room 872.
99252	1/23/01	AC	Work stoppage Mezzanine F temp below specifications for calibration, repair ASAP
99253	1/23/01	AC	Please regulate and keep the temperature constant below 80 degrees!
99255	1/23/01	AC	Please regulate and keep the temperature constant below 80 degrees! Shop 94105, electric shop
99257	1/23/01	AC	Need coolant in T58 manual test stand #1 / work stop
99264	1/23/01	AC	Repair, clean AC as per instructions
99266	1/23/01	AC	Overhead steam heater in warehouse need to have steam trap replaced, heater not working
99274	1/23/01	Vents	Overhead vent, repair or remove
99279	1/23/01	AC	Coolant leaking from T58 manual test stand #1 / work stop
99289	1/23/01	AC	Heater in the annex of 96334 leaking water when running.
99291	1/23/01	Vents	Need a six-inch sheet metal elbow and a two-foot section of pipe to direct the noisy filter exhaust away from the operators and direct it upward. See PMB shop. For dayshift sheetmetal.
99295	1/24/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
99308	1/24/01	Vents	Exhaust vent E4, XO1664, either has a bad pulley or belts are loose, emitting a loud noise while in operation. Located in old paint hanger, flight line side.
99309	1/24/01	AC	No heat
99314	1/24/01	AC	AEP area. No heat
99327	1/24/01	AC	Heater in the annex of 96334 leaking water when running.
99372	1/24/01	AC	Repair AC
99387	1/24/01	AC	Request check AC. Second day in a row that it has gone to 80 degrees after noon.
99394	1/24/01	AC	Request check AC. Second day in a row that it has gone to 80 degrees after noon.
99399	1/24/01	Vents	Replace motor in vent 188-3.
99402	1/24/01	Vents	Replace motor on vent 134-3
99491	1/25/01	AC	Steam heater in stripbarn is blowing nothing but cold air/ please repair ASAP
99497	1/25/01	AC	Numerous respiratory complaints. OSHA recommends check/replace heat duct filters. Clean mildew/mold around heat ducts.
99499	1/25/01	AC	Employees report a continuous stream of water coming off the roof over the office areas into the gutter downspout. They believe there is a leak of some sort on the roof. Steam or some type of heating unit?
99509	1/25/01	AC	No heat in 53 hanger bay
99519	1/25/01	AC	Temp on Mezzanine F has dropped below required limits. Shop 94201 is in a calibration work stoppage. Repair AC ASAP
99521	1/25/01	AC	Steam heater in strip barn is blowing nothing but cold air/ please repair ASAP
99532	1/25/01	AC	Please check out steam heat in bldg 245 and report findings attn: WC-50
99537	1/25/01	AC	T2 regulator inoperable work stop
99542	1/25/01	AC	Return air vent to AC in laser room is making a loud noise.
99543	1/25/01	AC	O.k. guys! It's Thursday now, we've been without heat all week. I put in a ticket Monday, guy came down and looked, haven't heard anything since, and we still have no heat. Help, please.
99550	1/25/01	AC	Hot temp reg. Inoperable: work stoppage
99558	1/25/01	AC	Check oil level in Trane compressors and record readings each shift. 6.3.658
99572	1/26/01	AC	H-46 hangar tech library modine heater leaking water on the floor.
99575	1/26/01	AC	Furnace is blowing cold air. Need a priority to fix.
99583	1/26/01	Vents	Check proper operation of make up air system and exhaust vent system of plating shop, bldg 4035.
99586	1/26/01	AC	Some people from maintenance came and worked on the steam several days ago and the heat hasn't worked right since. We knew this would happen. It was working fine before they messed with it. Please help!

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
99593	1/26/01	AC	Heat doesn't work
99597	1/26/01	AC	Mezzanine A penthouse no heat
99598	1/26/01	AC	94406 WC steam leak in attic hasn't been fixed. Steam has been turned off
99601	1/26/01	AC	Heat not working in heat-treat control room.
99602	1/26/01	AC	Requesting to have heat turned on in shop 93117-small and also shop 93111 small clean area POC shop supervisor.
99620	1/26/01	AC	Alright. Enough. It's freezing cold in here. My hands are so cold, it's hard to use my computer. Are we going to get any response from anybody or do we have to call out OSHA again? Help, please.
99637	1/26/01	AC	Heater in tubing area of shop leaking. Dripping in work area!
99670	1/26/01	AC	Leak over sling area. Must be steam condensate. Not raining.
99691	1/26/01	AC	Front AC has high temp on it and it is very hot in front of computer room. AC #x00310 (A217) need ASAP because it is very hot in here.
99715	1/29/01	AC	Adjust relocate unit as per instructions
99719	1/29/01	AC	Repair AC as per instructions
99721	1/29/01	AC	It is hot in here and we have no control. It is 85 degrees in some of our office spaces. Please send help ASAP.
99724	1/29/01	AC	Hot in here possible warranty
99729	1/29/01	AC	Temperature rising in clean room work stop
99733	1/29/01	AC	HF furnace room has lots of very cold air coming from HVAC ducts. Causing problems with furnace, preventing gas bottles from being heated enough to run furnace.
99753	1/29/01	AC	Furnace still doesn't work. Need a priority. The other heater repair couldn't fix it. I don't see why I have to send in another work order. Don't you have anyone that can fix a furnace. The first work order was sent in on 1/26/01, ticket order #99575
99808	1/29/01	AC	Repair heat on the AC in the equipment room.
99814	1/29/01	AC	Repair AC Trane unit
99815	1/29/01	AC	Repair AC as per instructions
99822	1/29/01	AC	Monitor chiller in 500 ton room, if any problems call
99825	1/29/01	AC	Repair AC as per instructions Trane
99826	1/29/01	AC	Repair leak on air handler as per instructions
99828	1/29/01	AC	Repair Mezzanine A AC
99843	1/29/01	AC	Clean room temperature climbing above normal limits 80 degrees and rising.
99848	1/30/01	AC	Extremely hot in shop. Need some AC badly. Please repair.
99850	1/30/01	AC	This is an ongoing problem that someone should be able to take care of. This is only the 10th or 15th work order called in for excessive heat in shop. Please help!

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
99865	1/30/01	AC	Request AC be checked to see if working properly. Does not seem to cool. It is unbearably hot in the training office of bldg 133. It is extremely hot and humid.
99867	1/30/01	AC	AC out in all three bonding rooms these is climate control rooms. Work stoppage thanks.
99869	1/30/01	AC	Heater is stuck on please relieve
99870	1/30/01	AC	Check filters and clean vents in shop area.
99871	1/30/01	AC	Ventilation system in cleaning line is out of balance. Must leave exterior door open to prevent cleaning line from alarming and automatic shutdown. Balance make-up air with exhaust ventilation.
99889	1/30/01	AC	Steam leak at air handler dripping in blast machine and shutting down operations. Work stoppage
99896	1/30/01	Vents	Vent/stack no 4188 V6 has a bad motor noise
99903	1/30/01	AC	The chiller for the hard anodize tank is down, needs repair ASAP. Work stoppage. Thanks
99923	1/30/01	Vents	Restroom vent fan making loud noise.
99932	1/30/01	AC	AC system is not operating
99936	1/30/01	Vents	Vent for paint spray booth stop working, work stoppage thank you
99952	1/30/01	AC	AC system is not operating
99965	1/30/01	AC	Mezzanine G in bldg 137 ceiling is leaking in computer room
99967	1/30/01	AC	Temp and humidity out of limit in bonding room.
99969	1/30/01	AC	AC in 6.3.651 office is not working. Please repair. Thank you.
99985	1/31/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
100000	1/31/01	AC	Leak from ceiling onto desk.
100001	1/31/01	AC	Repair AC
100026	1/31/01	AC	Balance air flow in the 20-ton AC
100028	1/31/01	AC	Install receptacle on the cooling tower chemical pump as per instructions
100047	1/31/01	AC	Freeze alarm going off in bldg 4224, main gearbox area. Bank# RMAU-1
100065	1/31/01	AC	Overhead heater is spraying hot water and steam all over shop
100067	1/31/01	AC	AC for communications closet keeps tripping the breaker. Room too hot for equipment
100068	1/31/01	AC	Remove duct to vent out boiler room
100085	1/31/01	AC	Wotan AC unit running very loud
100093	1/31/01	AC	We have a bad leak from the pent house on the roof that's over the anodize line, tank 30 thanks
100115	2/1/01	AC	Check chillers as per instructions
100123	2/1/01	AC	Wotan AC unit running very loud

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
100125	2/1/01	AC	Steam leaking from heater in drop hammer/foundry area. Heater is over the version press and repair will have to be scheduled with shop.
100129	2/1/01	AC	Perform one quarterly AC PM per the attached PM card. Record amount of time performing PM on the card. Link #V574400
100150	2/1/01	AC	Repair/replace controller on carrier chiller
100153	2/1/01	AC	Ceiling tile in center row, RH room, top floor "condo Mezzanine" (Mezzanine 19-3) is saturated with water. Possible leak. This is not related to renovation going on in that area. Thanks.
100179	2/1/01	Vents	Repair vent problem on the scrubber
100180	2/1/01	Vents	Replace covers on vents as per instructions
100181	2/1/01	AC	Repair/replace steam coil as per instructions
100182	2/1/01	AC	Adjust air for sewage spill as per instructions
100185	2/1/01	Vents	Please check for mold and clean, as required, the vents located around desk, upstairs in the H-60 area.
100202	2/1/01	Vents	Repair vent 4224-V-13; motor bad?
100220	2/1/01	AC	Inventory tools as per instructions and continue daily.
100222	2/1/01	AC	Inventory tools as per NADEP instructions daily
100236	2/1/01	AC	Check oil level in Trane compressors and record readings.6.3.658
100281	2/2/01	AC	No heat in high bay area.
100340	2/2/01	Vents	Louvers on make-up air system for cleaning line in bldg 4225 are broken. Fix or replace.
100361	2/3/01	AC	Repair heater as needed in the P3 rubber room. Heater will not come on.
100408	2/5/01	AC	Repair AC
100419	2/5/01	AC	Please replace filter in heat pump/AC.
100434	2/5/01	AC	Water leaking again over the production controls area
100435	2/5/01	AC	HVAC leaking over production control area in bldg 4225. X02149
100436	2/5/01	AC	No heat in the graphic arts area.
100438	2/5/01	AC	No heat in graphic arts
100439	2/5/01	AC	Repair heat this has been looked at several times
100442	2/5/01	AC	No heat in graphics arts
100486	2/5/01	AC	Repair insulation on the hard anodize tank
100492	2/5/01	AC	Replace repair register as per instructions.
100512	2/5/01	AC	Steam leaking from pipe joint on heater at far end of tubing shop.
100558	2/6/01	AC	AC air handlers in the shop need the filters changed/cleaned. Black lint like material is falling out of them. Sample of the material is available in supervisor's office.
100577	2/6/01	AC	Steam leaking from pipe joint on heater at far end of tubing shop.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
100606	2/6/01	AC	Service AC in old graphics arts area
100607	2/6/01	AC	Clean vents in old graphics arts area
100618	2/6/01	AC	Cold in the front office
100620	2/6/01	AC	Repair air handler 8 upstairs
100652	2/6/01	AC	AC air handler was blowing cool air. Now it is not. See for details.
100695	2/7/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
100729	2/7/01	AC	Repair propane filling station as per instructions, ASAP
100742	2/7/01	AC	Unit in office not working.
100750	2/7/01	AC	Relocate thermostat for local lodge 2297 see for details.
100759	2/7/01	AC	Repair Delimonene pump as per instructions
100760	2/7/01	AC	PM all water coolers
100774	2/7/01	AC	Replace AC as per instruction
100780	2/7/01	AC	Repair leak in the old 377 ton chiller room
100801	2/7/01	AC	Repair refrigerant leak in the number 1 AC Liebert ocnd
100802	2/7/01	AC	Repair AC duct as per instructions
100816	2/7/01	AC	Clean room temperature dropping rapidly
100844	2/8/01	AC	Need to adjust thermostat in prop shop (old rubber shop) temp 90
100869	2/8/01	AC	Overhead heater in tubing area still leaking. 2nd request.
100877	2/8/01	AC	Stand won't stabilize at 145 degrees work stop
100892	2/8/01	AC	Stand won't stabilize at 145 degrees work stop
100907	2/8/01	AC	Buff and grind room down needs help work stoppage
100946	2/8/01	AC	Temperature going up in clean room. Temp in controlled environment must be maintained at 72 +/- 5 degrees. Temp is now at 80 degrees and rising.
100952	2/8/01	AC	Troubleshoot T58 TC3 closed cooling tower electrical system to ensure fans operate correctly (water temp below 80 degrees F; no fans; 80 degrees F to 100 degrees F; low speed fan; over 100 degrees F; hi speed fan) had prior problem with both fans running at water temp of 32 degrees F.
100964	2/8/01	AC	Need to check hot water pump for proper operation for bldg
100970	2/8/01	AC	Front AC has a high head and humidification light on it. The buzzer in computer room keeps sounding off because the temperature is too warm in here. AC front 650 is in here checking it out now. It is extremely hot in here at the front right now at 20:0
101045	2/9/01	AC	Please turn the heat down or off in the hand blend room. It is too hot to work in there. Thanks
101047	2/9/01	AC	The air in the clean room is inoperable the temperature is now exceeding 80*. Work stop

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
101049	2/9/01	AC	It is so darned cold in here I am actually wearing gloves while typing in this work order. The thermostat is in another room and has a cover over it. I don't know what it is set on, but, it would have to warm up to freeze water in this office. Please help
101050	2/9/01	AC	Stand won't go to -25 degrees work stop
101064	2/9/01	AC	Need heat turned down,
101074	2/9/01	AC	Repair FMS control system monitoring Liebert no. 1 and 2 on Mezzanine G, bldg 137. Resolve problem with toggle switch used to override FMS.
101088	2/9/01	AC	Check oil level in Trane compressors and record readings. 6.3.658
101113	2/12/01	Vents	Repair vent 4224-42
101116	2/12/01	AC	No heat, in transportation area.
101133	2/12/01	AC	Repair leak on the AC
101144	2/12/01	AC	Heat-unable to maintain temperature. Thermostat set at 72, currently showing 68.
101151	2/12/01	AC	There are no heaters working in the H-53 hanger.
101156	2/12/01	AC	Classroom #9 is hot! He was in earlier this morning, but at that time we did not have anyone in the classrooms. Office is also getting rather warm.
101172	2/12/01	Vents	Repair vent 4224-17 and 133-134
101176	2/12/01	AC	Seal off outside air intake on backup AC (Trane packaged rooftop unit) serving the Mezzanine G computer room.
101211	2/12/01	Vents	Need maintenance to block off vent in ceiling above desk. It blows cold air on me all day.
101213	2/12/01	AC	No heat in vault please check and repair.
101250	2/12/01	AC	AC unit not working at all. Heat or cooling.
101254	2/12/01	AC	Flight check needs 3 new air filters size 16x25x1. AC unit could also use some preventive maintenance
101296	2/13/01	AC	Too hot in accounting office
101299	2/13/01	AC	AC unit not working at all. Heat or cooling.
101306	2/13/01	AC	The buff and grind room is down again we are in a work stoppage
101311	2/13/01	AC	Too hot in travel office
101324	2/13/01	AC	Too hot in accounting office
101328	2/13/01	AC	Unable to reach -25 degrees work stop
101351	2/13/01	AC	Repair refrigerant leak on the condenser
101369	2/13/01	AC	AC not working in climate control room
101383	2/13/01	AC	Please check AC. Temp is at 80 degrees and rising today.
101413	2/14/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.



Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
101419	2/14/01	AC	Air was set to 69 degrees at 2:00 yesterday because it was 81 degrees up here. Even set at 69 all night, this morning the temp is 76, so the air doesn't seem to be working correctly.
101428	2/14/01	AC	Please check AC. Temp is at 80 degrees and rising today.
101482	2/14/01	AC	Repair refrigerator
101494	2/14/01	Vents	Clean vents 9-17 in the carpenter shop
101558	2/15/01	AC	Install window unit in the johnson gAuguste room ASAP.
101565	2/15/01	AC	No AC. Very hot on 1 side of second floor.
101568	2/15/01	Vents	Need maintenance to block off vent in ceiling above secretary's desk in 210. It blows cold air on me all day.
101571	2/15/01	AC	Need maintenance to block off vent in ceiling above secretary's desk in 210. It blows cold air on me all day.
101575	2/15/01	AC	No AC. Very hot on 1 side of second floor.
101588	2/15/01	AC	Test stand will not achieve -25 degrees. Work stop
101596	2/15/01	AC	AC repaired on Tuesday & worked fine. AC now set to 65 degrees, but it's already 78 degree & will get worse as the day progresses. Needs immediate attention. Thanks.
101604	2/15/01	AC	Check failed compressor repair/replace as needed.
101607	2/15/01	AC	P3 rubber is entirely too hot causing difficulty to breath because of adhesives being applied to blades. Seems the heater is still on causing cure time of adhesives to increase making it dry out before rubber goods can be applied.
101609	2/15/01	AC	The AC over the laser room is still making loud noises and was turned in on ticket 99542, which has been closed.
101616	2/15/01	AC	Need overhead vent adjusted, please ASAP
101625	2/15/01	AC	Repair AC duct, back of 654
101627	2/15/01	AC	Repair AC duct, back of 654
101630	2/15/01	AC	Maintain AC not operating properly, possibly due to steam being cut off to shop when installing hot water heater in 188.
101632	2/15/01	AC	AC is not putting out like it should. Low on gas? Help.
101636	2/15/01	AC	Heat in shop is on and it is 87 degrees in shop please send some help. We need AC
101638	2/15/01	AC	Need some air it is very hot in our work areas. Thanks.
101646	2/15/01	AC	P3 rubber is entirely too hot causing difficulty to breath because of adhesives being applied to blades. Seems the heater is still on causing cure time of adhesives to increase making it dry out before rubber goods can be applied.
101648	2/15/01	AC	Need overhead vent adjusted, please ASAP
101650	2/15/01	AC	Unstop drain Mezzanine E roof unit
101651	2/15/01	vents	Exhaust blower in women's restroom emitting a strong electrical odor.
101668	2/15/01	AC	Check oil level in Trane compressors and record readings 6.3.658

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
101694	2/16/01	AC	Repair refrigerant leak on the Delimonene chiller
101702	2/16/01	AC	Need to replace thermostat.
101703	2/16/01	AC	Repair drain pan on the AC laser room
101704	2/16/01	AC	Repair T-64 test stand
101710	2/16/01	AC	Repair tubing on heat exchanger as per instructions
101713	2/16/01	Vents	Fix vent fans in mechanical room
101744	2/16/01	AC	Air compressor will not shut off. May overheat and cause damage
101747	2/16/01	AC	AC do not work too hot.
101772	2/17/01	AC	Need to have the exhaust system checked/repared and the AC system in the dispensing room in 4247 where hazmat is dispensed. Health/safety issue. Need ASAP.
101776	2/17/01	AC	Vacuum leak in floor between C6 and D6 poles in clean room.
101789	2/20/01	AC	High temperatures in computer labs in room 107 and 112 have lead to a work stoppage.
101790	2/20/01	AC	AC does not work too hot.
101792	2/20/01	AC	Heating unit not working no heat
101793	2/20/01	AC	HVAC unit needs to be checked - black smut coming out of duct work - may need filters changed - located in NC programming on Mezzanine E
101794	2/20/01	AC	T2 will not go down / work stop
101800	2/20/01	AC	The hot water system used for the heating of the plating tanks is down. This is a work stoppage. Thanks
101807	2/20/01	AC	No heat at all in high bay area.
101810	2/20/01	AC	Test stand will not hold 70 degrees / work stop
101813	2/20/01	AC	Repair heat exchanger on the Delimonene
101827	2/20/01	AC	No heat in component paint shop, bldg 137. Paint will not cure properly at this temperature. Please repair heating system.
101831	2/20/01	AC	Heating and cooling system in Sermetel room (component paint shop, bldg 133) is not operating properly. This Sermetel coating must be applied in a control temperature and humidity environment. Please repair AC.
101835	2/20/01	AC	No chill water. All test stands running hot potential work stop
101836	2/20/01	AC	No chill-water in RCA room.
101846	2/20/01	AC	Test stand running too hot work stop
101856	2/20/01	AC	Front lobby is very hot
101858	2/20/01	AC	Chill water down, ACC test
101876	2/20/01	AC	Test stand will not achieve -25 work stop 2nd request
101878	2/20/01	AC	Test stand will not achieve -25 work stop 2nd request

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
101886	2/20/01	AC	Thermostat cover needs replacing in shop area; cover is broken.
101889	2/20/01	AC	90 in her area - up stairs office 206
101897	2/20/01	AC	Hot upstairs in bldg 4470
101898	2/20/01	AC	T2 will not go down / work stop
101899	2/20/01	AC	Test stand running to hot work stop
101900	2/20/01	AC	Test stand will not achieve -25 work stop 2nd request
101901	2/20/01	AC	Test stand will not hold 70 degrees / work stop
101903	2/20/01	AC	The hot water system used for the heating of the plating tanks is down. This is a work stoppage. Thanks
101904	2/20/01	AC	Mech. #1 test stand will not get cold. Need freon: work stoppage
101916	2/20/01	AC	No heat in shop work stop material will not cure properly
101922	2/21/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
101924	2/21/01	AC	It has been 80 degrees or hotter in this bldg yesterday and it is just as hot this morning. Temp strip says 82 degrees. The heater and fans are running continuously.
101935	2/21/01	AC	AC in loft area down- complaining about temp in area. Need help ASAP ... Thanks
101941	2/21/01	Vents	Overhead exhaust fan in P-3 rubber room does not work. Safety hazard. Please repair ASAP.
101946	2/21/01	AC	Make daily checks as per instructions
101953	2/21/01	AC	Repair wotan lathe cooler not cooling work stoppage thanks.
101956	2/21/01	AC	Need some AC it is very hot in our work areas. Thanks.
101958	2/21/01	AC	Extremely hot in 525 office area
101987	2/21/01	AC	Hot! Split system is not working properly
101994	2/21/01	AC	T2 switch inoperable / work stop
102022	2/21/01	Vents	Clean vents and duct in carpentry shop.
102024	2/21/01	Vents	Replace bearings in exhaust system #214. Must be done on Saturday due to production requirements.
102034	2/21/01	AC	AC blows out hot air even when switch is on cool.
102037	2/21/01	AC	Fix AC unit on Mezzanine C major complaining going on.
102041	2/21/01	AC	Heating unit is unserviceable. No heat for three days
102068	2/21/01	AC	T-2 on test stand shut off by its self: work stoppage.
102072	2/22/01	AC	T2 switch inoperable / work stop.
102073	2/22/01	AC	No heat in high bay area. Need regulated temp 68-75 degrees to work for emergency H-46 floats
102076	2/22/01	Vents	Noise level has increased greatly during the last couple of weeks. It too loud. Check and repair as needed to reduce noise
102099	2/22/01	AC	Heating unit is unserviceable. No heat for three days

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
102109	2/22/01	AC	No heat, wing near flight line has no heat
102121	2/22/01	AC	Install damper on last duct on trunk line making a lot of noise.
102166	2/22/01	AC	Thermostat cover needs replacing in shop area; cover is broken.
102168	2/22/01	AC	HVAC unit leaking water in machine shop area during rainstorm.
102187	2/22/01	AC	Check oil level in Trane compressors and record readings. 6.3.658
102210	2/23/01	AC	Install thermostat covers on the thermostats in 659/654 office.
102211	2/23/01	AC	Relocate supply vent 2 each as per my instructions. This is over desk.
102212	2/23/01	AC	Clean equipment room; remove filters. Sweep floors,
102218	2/23/01	AC	Work stoppage no heat in the rubber shop area.
102248	2/23/01	AC	Too much heat in the dispensing room. Also check exhaust ventilation to assure adequacy.
102270	2/23/01	AC	Install air diverter on AC vent to spread out cold air. Too cold right under vent.
102307	2/23/01	AC	Doesn't work
102311	2/23/01	AC	2nd request. Please help! One part of office is very cold the other is warm.
102327	2/23/01	AC	Can another air vent be installed in the drawing files. The front counter area needs more circulation/air. The employees in the back area of the drawing files have more vents. So the temperature at the front and back is always different
102357	2/23/01	AC	Replace shorted condenser fan motor for AC 65923 040880 in bldg 4033. Discrepancy was found while doing PM under link #V618866.
102366	2/23/01	AC	Check wotan lathe chiller, replace contactor for condenser fan. (ran out of time) thanks.
102396	2/26/01	AC	Not getting chill water to dowty test stand / work stop
102397	2/26/01	AC	T2 system inoperable on manual test stand / work stop
102405	2/26/01	AC	Temperature rising in clean room. Need to maintain controlled environment per NAVAVNDEPOTINST 11100.1
102407	2/26/01	AC	Heater in CH-46 hanger adjacent to column I-28 is leaking on high power transformer
102410	2/26/01	AC	2nd floor of bldg 159 is hot & stuffy again.
102411	2/26/01	AC	AC will not cool at all in loft area!
102417	2/26/01	AC	Very warm upstairs in bldg 4188
102420	2/26/01	AC	AC on side B, bldg 159 is not operating.
102424	2/26/01	AC	Help, please. We're dying down here. We have no windows to open
102426	2/26/01	AC	Compressor A1 indicates high-pressure cut off; has not been running for awhile, error 51.
102428	2/26/01	AC	Thermostat is set too high, unable to correct due to the locking system that was installed. Request that someone come down and readjust thermostat. Shop- 96332
102429	2/26/01	AC	Chiller on the hard anodize is down, this is a work stoppage. Thanks

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
102436	2/26/01	AC	Please help! It is hotter than blue blazes in our office area. Thanks.
102438	2/26/01	AC	No hot water in eatery
102442	2/26/01	Vents	The two exhaust fans in the heat treat room is not exhausting fumes from room.
102446	2/26/01	AC	No AC in mixing room to hot to mix work stoppage.
102449	2/26/01	AC	Test stand won't get cold enough work stop
102450	2/26/01	AC	Test stand won't get cold enough work stop
102465	2/26/01	AC	Temperature was near 100 this a.m. tried to start AC as of noon it was 81 AC does not appear to be working. Needs attention.
102501	2/26/01	AC	AC not working on one half of second floor. We have a class going on and some of the students are complaining about the heat. Please fix as soon as possible.
102506	2/26/01	AC	T-2 will not achieve -25 degrees on T-58 mech #1 test stand: work stoppage
102520	2/27/01	AC	Heaters not working again. Need regulated heat to work for material. Material in facilities hold until heat repaired.
102529	2/27/01	AC	McQuay HVAC unit that supports the paint Sermetel room in bldg 4225 is not operational. Work stoppage! This will not allow us to spray paint Sermetel on aircraft engine parts.
102534	2/27/01	AC	Heating unit is unserviceable no heat
102557	2/27/01	AC	The temperature in the computer room is 60 degrees according to the display. It has an under temperature condition light, and says it is heating, but it seems to be blowing cold air.
102558	2/27/01	AC	T2 will not go to 145 degrees / work stop
102583	2/27/01	AC	Check out AC in 2297 union office
102598	2/27/01	AC	Check out controls for McQuay HVAC that services the paint Sermetel room in bldg 4225.
102619	2/27/01	AC	Ice machine in black aisle behind heat treat has quit working... Needs attention thanks
102623	2/28/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
102635	2/28/01	AC	Ice machine in hallway outside instrument (94101) is inoperable. Please repair. (#65923070977)
102656	2/28/01	Vents	Remove abandon ductwork connected to exhaust fan no. 137-320. Remove fan and seal resulting roof/wall openings.
102663	2/28/01	AC	The heat in petrie rubber room is off work stoppage
102676	2/28/01	AC	It is 85 degrees and rising in here. Please help us!
102683	2/28/01	AC	Chill water diaphragm control not working, test stand running hot. Hazard test
102703	2/28/01	Vents	Ventilation fans are not working correctly in heat treat room, bldg 4225. Please expedite!
102705	2/28/01	AC	T2 system is inoperable / work stop
102707	2/28/01	AC	Previous maintenance had not fixed the problem; a replacement fan was installed however no AC is coming through resulting in very hot office spaces.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
102715	2/28/01	AC	AC in instrument area getting loud again.
102719	2/28/01	AC	Located upstairs on Mezzanine A; men's head has no heat in restroom. Investigate and determine heat source. If radiator supply's heat check and repair.
102746	3/1/01	AC	Request maintenance of heat unit located in lower level east end of bldg (CASS-IPT). Current temperature 66 degrees.
102747	3/1/01	AC	Faulty heating element in T2 system causing major temp fluctuations
102762	3/1/01	AC	Heating unit not working no heat
102768	3/1/01	AC	No heat in the rotor head paint shop investigate - 35.00
102770	3/1/01	AC	Cold in the conference room
102810	3/1/01	AC	Please repair leaking AC unit located at station 5A.
102829	3/1/01	AC	Repair control system in paint area
102840	3/1/01	AC	Old ticket 102248 for too much heat corrected too well, now no heat.
102847	3/1/01	AC	T-64 fuel control test stand T2 inoperable. Work stoppage.
102887	3/2/01	AC	Buff and grind room is shutting off and on needs to be look at work stoppage.
102890	3/2/01	AC	Repair AC
102898	3/2/01	AC	Need someone to check our AC please. People are getting sick. Thanks.
102905	3/2/01	AC	Eatery in bldg 4224 - AC not working properly
102945	3/2/01	AC	The temperature is to high in the P-3 rubber room needs to be turn down work stoppage this a climate control room thanks.
102995	3/2/01	AC	Check oil levels in Trane compressors and record readings. 6.3.658
103018	3/5/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
103044	3/5/01	AC	Please adjust temperature in shop. Currently too 'hot', pneumatics shop, after going through front lobby of bldg 137 to hangar. 2nd shop on right.
103049	3/5/01	AC	Modine heater in Centact room leaking
103059	3/5/01	AC	T2 rising - won't hold 75 degrees
103088	3/5/01	AC	It is 62 degrees in the office. The climate control system is working in all surrounding offices.
103109	3/5/01	AC	Usual unit is acting up again. No heat.
103117	3/5/01	Vents	In hallway, upstairs, you can smell steam. It is being pulled into the office area, and may be cause to supervisor being congested all the time. Please investigate this as soon as possible. It may be health hazard.
103128	3/5/01	AC	Overhead AC, heat unit needs filters washed/cleaned. The filter has been cleaned once before, approx 3-4 months ago. This needs a PM card so it can be cleaned on a regular basis.
103143	3/6/01	AC	The temperature in our climate-controlled lab, which is supposed to be 77 F, is currently 56 F. Most tests cannot be run.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
103147	3/6/01	AC	At least 4 heaters need belts. One heater needs a new pulley. Two others are still down since before Christmas with internal problems.
103149	3/6/01	AC	Reset freeze stat at bldg 200 find out why it is still tripping report findings this is the second request. Attn: contractor
103150	3/6/01	AC	Clean equipment room, (already been completed.)
103151	3/6/01	AC	Repair controls as per instructions
103155	3/6/01	AC	Repair gas heat in the paint shop one is working one is not.
103168	3/6/01	AC	The heating units in the back of bldg 1798 is not working. It is not producing hot air. Could you please send someone here to look at it and repair?
103176	3/6/01	AC	No heat in spray booth, bldg 84.
103178	3/6/01	AC	Check and repair heat to bldg
103180	3/6/01	AC	It's 82 degrees in here. Please turn down the heat!!!
103186	3/6/01	AC	Our furnace is blowing cold air. Every time it turns cold our furnace blows cold air. Need fixed ASAP. Its cold in our shop.
103190	3/6/01	AC	Component paint shop, bldg 137, is too cold for paint to cure properly. This affects work throughput. Please repair heating system.
103196	3/6/01	AC	Check heat pump, bldg 84, for possible liquid refrigerant flood back. Report findings.
103205	3/6/01	AC	Remove steam coil and install new coil need pipe fitter for true love ASAP. Thanks.
103209	3/6/01	AC	AC in linear measurement room just quit. Urgent temp needs to be maintained
103212	3/6/01	AC	Need heat in 4 & 5 test cell. Employees are cold.
103260	3/7/01	AC	Request assistance plant accounting 3 new ACs in the production control area #19 in bldg 137 for PM purposes. Request data be obtained as follows: manufacturer, part number, model number, serial number.
103262	3/7/01	AC	Chronic heat and air problems. Thermostat follows the outside temperature. Currently 58 degrees in front of bldg and 54 in the rear portion of the bldg 129, upstairs.
103283	3/7/01	AC	No heat in right rear corner of accessory test area.
103285	3/7/01	AC	Makeup air handler (MAU1) replace steam coil, as per instruction. Work stoppage
103288	3/7/01	Vents	Dirty ceiling vents - area 167
103303	3/7/01	AC	Not enough heat
103307	3/7/01	AC	No chill water - test stands running hot; potential work stoppage.
103308	3/7/01	AC	No heat in lobby
103314	3/7/01	AC	Big Trane AC has a short in it.
103330	3/7/01	AC	Request that the manual thermostat be replaced with an automatic thermostat. Located at rear of bldg 129, upstairs (new extension).
103341	3/7/01	AC	Check out AC

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
103398	3/8/01	AC	System condensate cooling system/pwd lift station is unstable/low level condition; need fix. Thanks.
103420	3/8/01	AC	Overhead heater/AC unit was serviced last week and the filter was cleaned yesterday. When I turned on the heat this morning it blew cool air and then quit blowing at all. Help!! I turned the unit off.
103429	3/8/01	AC	Chilled water unit for water knife not working, water incoming 85 - 100 degrees. Machine over temping and shutting down. Need repairs ASAP. Work stoppage. Thanks
103432	3/8/01	AC	Check ACs
103459	3/8/01	Vents	Venting system still not pulling properly on alodine tank (D-24) per ih survey. Need to up grade motor or install bigger pulleys. Safety work stoppage
103472	3/8/01	AC	Unit that feeds computer floor in outer lab has a compressor fault (non-resettable). Lab area is getting too hot for equipment to run. Need assistance/repair immediately to keep equipment running. This is a work stoppage!!!
103483	3/8/01	AC	Check front lobby for no heat and blowing out cold air.
103487	3/9/01	Vents	Request someone come over and look at the vents in the H53 hanger. When painting you are able to smell it out in the hallway & and on the 2nd floor. Send a copy to hazmat waste to remove filters in booth if needed. We need this done ASAP.
103507	3/9/01	AC	Heater in strip barn has multiple steam leaks/ please repair or replace
103509	3/9/01	AC	Request maintenance of heat unit located in lower level southeast wing of bldg tri-plex rep says false thermostat readings are being to reported to central heating unit. 2nd occurrence this week (64-66d).
103510	3/9/01	AC	Overhead heater leaking heavily/ please repair
103553	3/9/01	AC	Check chill water system back of bldg 137 for shops of 93500. Loop water system has alot of slugs in it.
103566	3/9/01	Vents	Provide assistance to engineering in troubleshooting industrial ventilation system in bldg 3767.
103584	3/9/01	AC	Overhead AC was on after repairman serviced the unit this morning, but at lunchtime, the unit quit running and blowing. Malfunction code is P6 then 0, alternating.
103585	3/9/01	AC	Door won't close on air conditioner located in 22400 office
103586	3/9/01	AC	T-64 test stand #1 T2 system is not operating.
103609	3/9/01	Vents	Overhead vents will not close in AV8 hush house
103612	3/9/01	AC	Check oil level in Trane compressors and record readings. 6.3.658
103630	3/12/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
103637	3/12/01	AC	Leak in overhead pipe. It's been fixed three times, leaks worse now then it ever has.
103683	3/12/01	AC	Test stand will not go -25 degrees/work stop
103697	3/12/01	AC	No heat
103720	3/12/01	AC	Very warm in shop. Can we got some cool air. AC not cooling.
103725	3/12/01	AC	Mezzanine E-8 act. Not cooling



Ticket Number	Date	Problem Type	Description
103727	3/12/01	Vents	Smell something burning from vents
103732	3/12/01	AC	Please adjust temperature in shop. Currently to "hot"
103749	3/12/01	AC	Test stand will not go to -25 degrees/work stop
103765	3/12/01	Vents	Ventilation in the H-53 paint hanger is operating with extreme positive pressure, causing the doors to fly open. This happens when the system is in the electro-static paint mode.
103769	3/13/01	AC	Heating an air in the upstairs area of bldg 4035 is not working. Thanks
103771	3/13/01	AC	Good morning. It is early, and it is already 75 degrees in our office and some training rooms. We have a full schedule of classes today, and it of course is going to be 'warm' today. Thank you
103772	3/13/01	AC	The heat is running full blast at our end of the bldg we need it shut off. Thanks
103783	3/13/01	AC	Chill water temperature rising on ASE test stands/work stop
103784	3/13/01	AC	Test stand won't achieve - 25 degrees/2nd request/work stop
103799	3/13/01	AC	P-3 rubber room temperature is to high this is a temperature control room work stoppage.
103806	3/13/01	AC	AC not working again - very stuffy on half of 2nd floor.
103812	3/13/01	AC	Still need some "AC". Second call. Please send help.
103823	3/13/01	AC	Overhead filter in office (avionics office -rear of bldg on left hand side of hall) is emitting excess dust and small trash particles.
103834	3/13/01	AC	Individual room AC is not operating. Equipment in this room cannot be operated.
103835	3/13/01	AC	Too much heat in the branch head office
103839	3/13/01	AC	Heat will not go off in the disburse tech library area, bldg 133. Black smut and strange odor came out of heat unit. Questionable fire/safety/environmental hazard? Contact for directions.
103842	3/13/01	Vents	Ventilation in H-53 hanger working under extreme positive pressure
103845	3/13/01	Vents	Ventilation in the H-53 hanger is working under extreme pos pressure
103850	3/13/01	AC	Test stand won't achieve -25 degrees/ 2 ed request/work stop.
103855	3/13/01	AC	Test stand running too cold/work stop
103867	3/13/01	AC	It is 80 degrees and rising!!!!
103873	3/13/01	AC	Repair AC in Sermetel room of component paint shop, bldg 133.
103887	3/13/01	AC	The system is giving us problems again. Hot in one area and extremely cold in the other area. Please help!
103908	3/13/01	AC	AC is not working. Second request from this office!!
103920	3/13/01	AC	It's hot in here!
103936	3/13/01	AC	AC will not come on. It is 80 degrees in our workspaces. Help!
103975	3/14/01	AC	Repair AC in the Mezzanine G computer room (work stoppage) attn: tri-plex
103982	3/14/01	AC	Check chillers as per instructions

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
103987	3/14/01	AC	Problem with water solenoid and alarm sensor in AC unit. Please make repairs.
103988	3/14/01	AC	Repair valve on the Mezzanine B AC
103989	3/14/01	AC	Adjust oil level in the 383 chiller as per instructions
103990	3/14/01	AC	Install wiring harness for air dryer
103993	3/14/01	AC	Repair/replace injectors as per instructions. Attn: Cape Carteret
103997	3/14/01	AC	Check pump noise on the new chillers as per instructions
104017	3/14/01	Vents	Please check ventilation and heating system. No air at all coming from ducts. Thanks!
104031	3/14/01	AC	Hot in the bldg AC not working ASAP
104043	3/14/01	AC	Still no cool air (AC). Repairman came yesterday, but it's still not working. Please check again.
104051	3/14/01	AC	Check out AC
104054	3/14/01	AC	Temperature is too hot (80) when temperature outside is above 60 or so.
104055	3/14/01	AC	AC is not automatically coming on and employees are very uncomfortable from the heat.
104087	3/15/01	AC	Check out cooling system for Streurs mounting press; mounting press is not the problem per company. The cooling system is the under the table type. Please see POC for more info and have POC sign ticket.
104091	3/15/01	AC	Heating/cooling system inoperable/work stop
104097	3/15/01	AC	Please repair air handler in final assy area. It is not working. Repair ASAP! Thanks.
104105	3/15/01	Vents	Vent #137-72 in tank testing area is leaking internally. Water is dripping onto top of varsol tank. Needs attention immediately. See for location
104113	3/15/01	AC	Cannot reach -25 degrees/work stop
104114	3/15/01	AC	No heat in corrosion barn/ please repair ASAP
104131	3/15/01	AC	2nd request. The AC is really cold in this office please assist!!!
104152	3/15/01	AC	Please repair air handler for the E-2 mod room and glass area. Humming coming from motor, and no airflow. Must be climate-controlled area.
104172	3/16/01	AC	A water leak has deteriorated the ceiling tiles in my office. Request replacement of the damaged ceiling tiles.
104195	3/16/01	AC	T2 temp rising/work stop
104203	3/16/01	Vents	Clean booth and install filters vent 137-110
104266	3/16/01	AC	Air conditioning still not working adequately. 4th call. Please.
104281	3/16/01	AC	Check oil level in Trane compressors and record readings
104292	3/17/01	Vents	Air vent that is located in the welding area of bldg 1798 is not working. Please send someone to repair.
104295	3/19/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
104296	3/19/01	AC	T58 mech. 5 stand will not reach -25. If it does reach -25 it will only stay there approximately 2-3 min., and then that will be the only time in a ten-hour day. Work stoppage
104304	3/19/01	AC	Repair AC heat unit in computer repair room
104306	3/19/01	AC	Heating unit is not working no heat
104310	3/19/01	Vents	Identify start/stop location and control operation. Report to bldg 84.
104320	3/19/01	AC	RCA room has no chill water.
104322	3/19/01	AC	Heater is not working. Keeps going to standby
104323	3/19/01	AC	Adjust temp in clean room
104329	3/19/01	AC	Johnson Control valve leaking
104333	3/19/01	AC	Unit # 1 at the rear of the bldg has a flashing alarm light. Unit # 2 has a warning message.
104343	3/19/01	AC	Heat does not work in upstairs part of the plating facility needs a new steam valve. Thanks
104350	3/19/01	AC	Contractor in this morning - system down - humidity too high bearings are sweating beginning to corrode.
104355	3/19/01	AC	It is very hot in shop please adjust.
104358	3/19/01	AC	Manual T64 test stand #1 is down due to not being able to reach -25 degrees work stoppage
104365	3/19/01	AC	No heat in graphic arts or photo lab
104394	3/19/01	AC	Temp is approaching 80 degrees in office. Please check to see if chiller is on line.
104411	3/19/01	Vents	Replace the vent
104418	3/19/01	Vents	Repair motor on vent #5
104420	3/19/01	AC	Request all ACs at bldg 200 be checked to see if they are plant accounted. If yes, please provide plant account numbers, if not, please provide mfr, type of unit, size of unit, P/N, S/N so they can be added to PMs.
104421	3/19/01	AC	AC in left hand side of lofting area not working. Burnt smell coming out of cabinet. Climate controlled area.
104426	3/19/01	AC	Pumps on vapor need to be fixed ASAP work stoppage
104429	3/19/01	AC	T-64 mech # 7 test stand will not get warm" work stoppage
104431	3/19/01	AC	Front AC making noise. Located on Mezzanine G computer
104488	3/20/01	AC	Repair vent stack and support cables on gas heater for bldg 1006/1007
104513	3/20/01	AC	Problem with water solenoid and alarm sensor in AC unit please make repairs
104515	3/20/01	AC	Pull wire from Liebert AC as per instructions
104537	3/20/01	AC	AC blows out hot air. Thermostat says 70 but really is 90 degrees.
104571	3/21/01	AC	Filter in AC heat pump needs changing.
104587	3/21/01	Vents	Evaluate vent ducts for repairs (10 each above labs)

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
104606	3/21/01	AC	Buff and grind room is down work stoppage
104608	3/21/01	AC	T58 mech. #5 stand will not go below -10 again. Work stop.
104615	3/21/01	AC	T58 mech. #5 stand will not go below -10/work stop
104622	3/21/01	AC	Fix AC electrical plug, per fire previous survey 2/22/01
104662	3/22/01	AC	Heater in can 1378 not working.
104677	3/22/01	AC	Humidifier H-2 in mechanical room on Mezzanine F seems to be not working. This humidifier is used in conjunction with 3 other humidifiers to control the humidity on Mezzanine F. Repair if inoperable.
104687	3/22/01	AC	Snack shop needs AC turned down
104705	3/22/01	AC	Heater in walk-in booth area leaking/ please repair or replace
104709	3/22/01	AC	HVAC system that supports the blasting room in bldg 4225 is not heating area.
104722	3/22/01	AC	2 of the rooms in our area are extremely cold, yet the other area is too hot. Please check system.
104746	3/22/01	AC	T58 mech #5 stand will not go below -10 again. Work stop
104747	3/22/01	AC	Request that the filters be changed on all ducts throughout the office on Mezzanine C. Clean all grills.
104749	3/22/01	AC	Request a system balance check of the supply and returns throughout the office on Mezzanine C. If excessive draft still remains, possible relocation of a return grill may be required.
104755	3/22/01	AC	T-58 flow divider test stand is unable to achieve -10 degrees: work stoppage
104771	3/23/01	AC	W/O to have AC system balanced in Mezzanine B (298) in bldg 83 training area.
104790	3/23/01	AC	AC. Trips breaker in break room
104806	3/23/01	AC	No chill water on ASE test stands/work stop
104824	3/23/01	Vents	Manufacture vent cap as per instructions.
104850	3/23/01	AC	Install AC smoke alarm as per instructions. RCA room. 133
104885	3/24/01	AC	Check oil levels in Trane compressors and record readings second shift
104897	3/26/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
104907	3/26/01	Vents	Repair vents over nickel line
104908	3/26/01	AC	AC in tach room (in instrument shop) inoperable
104910	3/26/01	AC	There is no heat in the rear part of the office upstairs.
104927	3/26/01	AC	Steam heat has quit working, no response from the control unit. Thank-you
104946	3/26/01	AC	Heating vent in avionics department office blowing cold air only. Office is first door on right as you come in the front door of bldg 4033.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
104966	3/26/01	AC	Temp is 80 degrees and climbing. No air coming out of vents. Please check chiller. (this is second Monday in a row we've had this problem.)
104987	3/26/01	Vents	Ventilation system down
104988	3/26/01	AC	Temperature in excess of 80 degrees.
104991	3/26/01	AC	Repair flame detectors in new part of bldg 245. Attn: WC-50
105019	3/26/01	AC	T-64 fuel control test stand T2 circuit breaker keeps popping. Work stoppage.
105067	3/27/01	AC	Mitsubishi HVAC system inoperable, error code P8 is displayed on the thermostat control. Office located next to the technical library.
105068	3/27/01	AC	Follow up to ticket #104966. Still no airflow in office today. Temp is 76 and climbing. Please respond!
105079	3/27/01	AC	Union shop is too hot
105127	3/27/01	AC	Follow up to tickets 104966 and 105068. Air is moving now, but temp is still 78+ degrees. Do you think we can get it fixed by tomorrow?
105148	3/28/01	AC	The heating unit, above the front roll-up door of bldg.1798, is leaking steam and water and causing a hazardous area on the floor. Please have it repaired.
105151	3/28/01	AC	Heaters are inoperable, blowing out black soot. Located in tail & intermediate test cell.
105154	3/28/01	AC	No heat -- 62 degrees in the bldg
105156	3/28/01	Vents	Repair vents 4032-4
105157	3/28/01	Vents	The air vent in the welding area of bldg 1798 is not working. Please send someone to repair it.
105161	3/28/01	Vents	Assist engineering in trouble shooting blast booth, binks system at bldg 4032
105166	3/28/01	AC	Heater in walk-in booth area leaking/ please repair or replace
105167	3/28/01	AC	Heater in walk-in booth area leaking/ please repair or replace
105168	3/28/01	AC	Heater in walk-in booth area leaking/ please repair or replace
105236	3/28/01	AC	HVAC system is keeping Sermetel room too hot! This room has a spray booth controlled by a McQuay HVAC unit. Please set temperature lower to 65 degrees F. Urgent! Work stoppage
105278	3/29/01	AC	Install check valve on number two screw compressor ASAP note still working on this unit
105280	3/29/01	AC	Replace belts on all four AHU 5 in the rotation electric shop AC.
105287	3/29/01	AC	It has been getting very hot in here all week. It's currently 80 degrees at my desk. Please turn down the heat!! Thanks!
105292	3/29/01	AC	Cool air flowing (AC running?) In 614 section. Temp was 69 F and cool air blowing from the vents. Other sections are comfortable. This was reported by code 614. Contact 611 engineering if there is a design deficiency in the system.
105298	3/29/01	AC	Chiller not cooling water. Starting to form ice on cooling unit.
105308	3/29/01	AC	Tank #131 will not heat up. Work stoppage. Thanks

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
105321	3/29/01	AC	Please change filters in AC unit - also I was told that several filters in the roof unit are missing. The mech. fixing the heat problem (ref ticket #104927) said that these missing filters are AC not heat, so they can't replace them. Thank-you
105337	3/29/01	AC	AC unit that serves code 6.2.96100, office, 960 SBU, Mezzanine A, bldg 133 is inoperable. Appears thermostat or AC unit is not working properly.
105359	3/30/01	AC	McQuay unit that supports the old pack process room in not operating. Same unit supports the mixing paint room in bldg 4225.
105361	3/30/01	Vents	Penthouses on the roof are not operating. This is causing a problem with the doors not wanting to open and they slamming shut. This is going to hurt someone. Thanks
105372	3/30/01	AC	AC unit that serves code 6.2.96100, office, 960 SBU, Mezzanine A, bldg 133 inoperable. Appears thermostat or AC unit is not working properly.
105375	3/30/01	AC	Repair AC in office Mezzanine A
105396	3/30/01	AC	Please cut off the heat. Numerous personnel are complaining of heat exhaustion. Thanks
105397	3/30/01	AC	Too hot in office
105417	3/30/01	AC	Request the 10 ACs in bldg 200 and one AC in bldg 137 be plant accounted for PM purposes. Info and tags can be picked up from bldg 84.
105425	3/30/01	AC	There is a fluctuation in temperature on Mezzanine F between one end of the Mezzanine And the other. Repair as soon as possible. Temp has exceeded limits for electronic calibration in one end of the Mezzanine.
105426	3/30/01	AC	Can you please check to see why our AC is not working ASAP. Thank you
105431	3/30/01	AC	Redesign of bldg 143 has changed layout. Please recheck all cooling parts of QA as cooling doesn't seem to be working. See for more information.
105443	3/30/01	AC	Repair AC for Sermetel paint room. This is a recurring problem.
105493	4/2/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
105494	4/2/01	AC	Extremely hot in shop...over 80 degrees. Probable safety hazard. Please fix AC.
105502	4/2/01	AC	Hard anodize is down, temp is too high. Work stoppage thanks
105504	4/2/01	AC	Heating unit not working no heat
105522	4/2/01	AC	Unit going out on high head pressure, humidity sensor, & bulbs not working. Dehumidifier and reheat not working. Status lights not working. Discrepancies found during PM on link v701549.
105554	4/2/01	AC	No chilled water for metal spray operation. Need chilled water to operate. (work stoppage)
105559	4/2/01	AC	Clean room too hot.
105560	4/2/01	AC	Manual test stands running too hot/work stop
105594	4/2/01	AC	AC has loud vibration noise while operating. Located behind old 950 division office.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
105601	4/2/01	AC	Third Monday in a row! Temp is 80 degrees and climbing. Please determine the cause.
105603	4/2/01	AC	Smells something burning in bearing room
105610	4/2/01	AC	Request AC unit for 2nd floor of bldg 4224 be checked for proper operation. Temperature in shop 94206 is 78 degrees and climbing. Sent 4/2/01 at 1330.
105626	4/2/01	AC	Work area too warm. Adjust thermostat to lower setting
105655	4/3/01	AC	The vent over the secretary's desk puts out all the air for this section - however, the vent on the other side of the office puts out little air. Can air be redirected to other vent? Too cold on one side, too hot on the other.
105665	4/3/01	AC	Assist. Electronics w/problem on the machine attn: Ellis Electric work stoppage
105683	4/3/01	AC	Perform work per the attached.
105684	4/3/01	AC	Perform work per the attached.
105686	4/3/01	AC	Perform work per the attached.
105688	4/3/01	AC	Request air handler servicing test cells 4 & 5 be checked out for proper operation. Check motor amperage, inlet louvers for proper operation, belt tightness, filters, etc
105698	4/3/01	AC	Breaker keeps tripping on wotan compressor. Please check compressor and fan motor.
105699	4/3/01	AC	Heat won't shut off at switch
105708	4/3/01	AC	We need the heat in the hand blend area turned down
105726	4/3/01	AC	Check AC is Mezzanine of bldg 83
105740	4/3/01	AC	Temperature in bldg this afternoon 78+. Please re-regulate air flow in bldg 143.
105764	4/4/01	Vents	Request investigation of bldg 159s vents and stacks to determine if they should be on PM.
105789	4/4/01	AC	Repair air handlers as per instructions
105796	4/4/01	AC	Make connections to pneumatic controls provide estimate
105816	4/4/01	AC	AC not working again on 2nd floor. Thanks!
105825	4/4/01	AC	Secure heat in back section of b133
105836	4/4/01	AC	I have the temperature set to 70 degrees and it is up to 78 degrees in room 123 U11 960 action center Mezzanine thanks
105855	4/4/01	Vents	Meet with engineering to discuss repair of scrubber mounts and rust problem. Discrepancy found while performing PM on link #'s V638307, V638308
105857	4/4/01	AC	Air handler #2 located bldg 159 penthouse has been shutdown by FMD personnel working on another area. The air handler was making a loud noise.
105859	4/4/01	AC	Extremely hot in the hand blend
105892	4/5/01	AC	The hard anodize tank is still not cooling down, work stoppage. Thanks
105906	4/5/01	Vents	Vents are shut down, they will not restart work stoppage

Ticket Number	Date	Problem Type	Description
105950	4/5/01	AC	Too cold in shop
105968	4/5/01	Vents	As per fire marshal, exhaust filters in the floor need to be cleaned out in the paint side of final finish.
106011	4/6/01	Vents	Evaluate power problem with vent. Discrepancy found during PM on link #V672086.
106012	4/6/01	Vents	Change out motor in vent. Discrepancy found while performing PM on link #V672085.
106017	4/6/01	AC	Reinstall fan motor on woton machine
106018	4/6/01	AC	Temperature too hot in the room. Needs repair.
106036	4/6/01	AC	Fan in AC & heat system making load noise
106060	4/6/01	AC	AC in hot air channel needs to be serviced. Air output not cool enough.
106061	4/6/01	AC	Check oil level in Trane compressors and record readings each day. (6.3.658)
106063	4/6/01	AC	Check operation of chillers second shift, and record readings each day. Bldg 4224 shop 95000
106064	4/6/01	AC	Check operation of chillers on second shift, take and record readings each day. Bldg 4225, shop 06111
106065	4/6/01	AC	Check operation of chillers on second shift, take and record readings each day. Bldg 4032, shop 43000
106066	4/6/01	AC	Check operation of chillers on second shift, take and record readings each day. Bldg 133, shop 96000
106077	4/6/01	AC	Old mechanical #1 test stand refrigeration is out.
106099	4/9/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
106100	4/9/01	AC	AC leaking water, leaking coming from the roof, need repair ASAP. Safety hazard.
106101	4/9/01	AC	Very, very hot in shop. Please turn on some AC.
106105	4/9/01	AC	Temperature in the blending room is in excess of 110 degrees. Result in work stoppage
106110	4/9/01	AC	No AC in several areas of prop shop work stoppage in bonding areas
106111	4/9/01	AC	AC not working. It is 78 degrees in here right now and will get much worse today.
106114	4/9/01	AC	Noise coming from vent like a grinding sound. Sounds like fan is restricted or something in the way of normal function.
106121	4/9/01	Vents	Repair broken tension on mounting bracket for vent 137-216. Discrepancy found while performing PM on link #V530119
106122	4/9/01	Vents	Blast blade off waterfall exhaust (vent 137-216). Discrepancy found while performing PM on link #V530119
106123	4/9/01	AC	No AC in disb lib, across from Mezzanine E
106124	4/9/01	Vents	Remove strip set screw and re-trap bolt holes for vent 137-216. Discrepancy found while performing PM on link #V530119
106128	4/9/01	AC	T58 manual test stand number one will not achieve -25 degrees T2 temperature. Work stoppage
106129	4/9/01	AC	Overhead heater in prep side of hanger is leaking water very bad. Need this area to work on AC and it is causing problems. Please look into this ASAP. Thanks.



Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
106130	4/9/01	AC	No AC in bldg
106140	4/9/01	AC	AC not working in shop 94405 and 94403
106145	4/9/01	AC	AC will not come on line help!!!!!!
106147	4/9/01	AC	AC is not working. Heat/humidity will soon cause equipment down time!!
106149	4/9/01	AC	Unstop floor drain in front chiller equipment room
106150	4/9/01	AC	No AC in disb lib, across from Mezzanine E
106154	4/9/01	AC	Room AC does not work properly. Does not cool very well. It makes a lot of noise with very little response.
106163	4/9/01	AC	Turn on AC in accessory test area/note: system secured
106167	4/9/01	AC	It is very warm in the bldg
106170	4/9/01	AC	Please turn heat off and air on we are suffocating over here
106176	4/9/01	AC	P-3 rubber room AC not working work hindrance
106181	4/9/01	AC	One of the AC units in the ramp bldg, the one on the end by rollup door, will not come on. Breaker on roof may be tripped, was cut off last year
106183	4/9/01	AC	AC needs to be turn on in shop 96332. 90 degrees in shop.
106184	4/9/01	AC	Repair float as per instructions.
106185	4/9/01	AC	Repair hot water pump bldg 133
106187	4/9/01	AC	Repair T-58 test stand
106188	4/9/01	AC	Check out and start York chillers the 377-ton loop bldg 133.
106189	4/9/01	AC	Reinstall eatery air package conditioner door and check unit operation bldg 133 eatery
106192	4/9/01	AC	AC in computer room has high head pressure
106199	4/9/01	AC	AC does not respond to thermostat. It is suffocating hot in the office area. Please help!
106218	4/9/01	AC	Purge air is too hot on ASE test stand # 5. Work stoppage
106228	4/9/01	AC	Please turn the heat off in bldg 133.
106230	4/9/01	AC	AC for HTS area inoperable.
106233	4/9/01	AC	Help, please!!! We have no AC, and no windows we can open. Please come check. What's the status on the AC in this part of the bldg there was a problem with parts at the end of the season. Is that still true?
106241	4/9/01	AC	AC is running continuously and not cooling
106242	4/9/01	AC	Check air in ASKARS seems to be warm
106245	4/9/01	AC	One condenser fan not turning. Blade bent and hitting fan cage.
106248	4/9/01	AC	T-58 flow divider test stand chill water inoperable. Work stoppage.
106256	4/10/01	AC	Temperature on Mezzanine F will not regulate. Temp is dropping below limits. Repair as soon as possible.

Ticket Number	Date	Problem Type	Description
106257	4/10/01	Vents	Please check scrubber CR2R exhaust system on roof of plating shop. Fan is making alot of noise.
106263	4/10/01	AC	AC to computers not working and exhaust fan not working properly.
106266	4/10/01	AC	AC not working, work hindrance quit working late PM P3 rubber room
106268	4/10/01	AC	The #1 unit AC is not blowing cold air. It's only blowing out warm air. AC is located in the ramp bldg in shop 93552 in bldg 137.
106276	4/10/01	AC	AC is down
106281	4/10/01	AC	AC is still not functioning very well in this area. It's extremely stuffy in here this morning. Please come check.
106286	4/10/01	AC	Repair AC
106291	4/10/01	AC	Problems with system again. Cold in one area warm in the other.
106292	4/10/01	AC	Replace gate valve on #4 air handler and re-insulate
106295	4/10/01	AC	Chill water inoperable on T64 # 1 manual test stand. Work stoppage
106304	4/10/01	AC	Service freon. Unit would not chill calibration fluid.
106308	4/10/01	AC	AC is still not functioning very well in this area. It's extremely stuffy in here this morning. Please come check.
106309	4/10/01	AC	Problems with system again. Cold in one area warm in the other.
106311	4/10/01	AC	Repair AC
106312	4/10/01	AC	Chill water inoperable on T64 # 1 manual test stand. Work stoppage
106316	4/10/01	AC	AC is dripping water on floor
106320	4/10/01	AC	Refrigerator is not cooling. The past two days I have heard a switch clicking on to run the compressor. Right now this refrigerator is inoperable. This unit is less than six (6) months old.
106321	4/10/01	AC	We have a drain stopped up therefore water is dripping from the AC.
106323	4/10/01	AC	AC coils on three Sciaky M5 automated welding machines need cleaning.
106334	4/10/01	AC	AC the annex needs troubleshooting. The unit hums and trips the circuit breaker.
106336	4/10/01	AC	Repair pneumatic controls, (work stoppage!) On the air handlers in the penthouses on the roof of 133. Also check the operation of the air handlers. Attn: Cape Carteret Inc. Thanks
106337	4/10/01	AC	Purge air in the 500 ton system chill water lines in the 133 old part bldg ASAP
106343	4/10/01	AC	Need the heaters turned off
106346	4/10/01	AC	Heat will not cut off. Over 100 degrees in work area!
106354	4/10/01	AC	Room temp is 80 degrees, need repairs completed.
106368	4/10/01	AC	Room temp is 80 degrees, need repairs completed.
106393	4/11/01	AC	AC makes loud noise at startup and when compressor kicks on. Its a friedrich AC.
106402	4/11/01	AC	AC not cooling very well. A new section, suite 62, has been opened and I can't find a thermostat for that area.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
106407	4/11/01	AC	AC not working (usual unit). Call POC if more info is needed.
106415	4/11/01	AC	Makes so much noise can't hear telephone or radio in dispatcher office.
106428	4/11/01	AC	No AC in 4 & 5 test cell
106432	4/11/01	AC	Controlled environment work area is at a work stoppage for air temp above limits. Supposedly repaired 4-9-01, lasted approximately 4 hours.
106439	4/11/01	AC	No cool air in 940 SBU area across from supervisor's office.
106440	4/11/01	AC	Humidity in clean room is 73%. Max allowed 40% +/- 10/work stop
106441	4/11/01	AC	Compressor in pneumatics has high temp alarm.
106446	4/11/01	AC	Compressor in pneumatics has high temp alarm.
106447	4/11/01	AC	No cool air in 940 SBU area across from supervisor's office.
106448	4/11/01	AC	Controlled environment work area is at a work stoppage for air temp above limits. Supposedly repaired 4-9-01, lasted approximately 4 hours.
106458	4/11/01	AC	AC is broken in the maintenance shop
106467	4/11/01	AC	No cool air in 940 SBU area across from supervisor's office.
106474	4/11/01	AC	The system is not working again. Very cold in all areas. Help!
106482	4/11/01	Vents	Manufacture shaft yoke per D&J specifications.
106487	4/11/01	AC	AC stop working in CH-46 pool, urgent request due to moisture on RFI parts.
106496	4/11/01	AC	Heater is still on in ASKARS material section. Please turn off and turn on the AC.
106498	4/11/01	AC	AC in hot air channel needs to be serviced air output not cool enough.
106507	4/12/01	AC	AC is running but it is not cooling
106511	4/12/01	AC	No chill water to ASE test stands/work stop
106522	4/12/01	Vents	As per fire marshal, exhaust filters in the floor need to be cleaned out in the paint side of final finish.
106529	4/12/01	AC	The AC in 96331 annex is not working and has not worked in the past two day. We are in an area where cannot open the doors for alternate airflow.
106552	4/12/01	AC	The temperature in the calibration lab is getting colder by the minute. A work stoppage will be imminent when the temperature falls below 69 degrees. Require immediate attention--panel must need to be adjusted.
106554	4/12/01	AC	Test stand running too cold/work stop
106558	4/12/01	AC	AC over 157 room sounds like a belt maybe about to break.
106584	4/12/01	AC	AC is leaking water in the telephone room
106588	4/12/01	AC	Repair AC in the break room of the component paint shop, bldg 137.
106589	4/12/01	AC	Repair AC in the break room of the component paint shop, bldg 137.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
106604	4/12/01	AC	Check AC in bonding room and 423
106611	4/12/01	AC	AC not working in clean room in bldg 133: work stoppage
106617	4/13/01	AC	Perform work per the attached.
106624	4/13/01	AC	Do not have any chill water in the RCA area.
106629	4/13/01	Cooling Tower	T58 mech. 1 has excessive fuel temp chiller may be down. Work stop
106634	4/13/01	AC	Perform work per the attached.
106635	4/13/01	AC	Perform work per the attached
106638	4/13/01	Vents	Remove vent covers from ceiling fans in cans
106645	4/13/01	AC	Condensation is bldg up off the AC ducts and dripping onto the overhead insulation, which is now soaked, and is starting to leak into the office area. We are located in the old hazardous material office at the back of the bldg
106674	4/13/01	Vents	Request information be provided to the property management branch regarding new ventilation system for capturing soldering fumes installed for 96331 IAW task 111225. \$22.50/hour
106708	4/13/01	AC	Water dripping in floor.
106710	4/13/01	AC	Repair AC in Sermetel room, component paint shop, bldg 133.
106717	4/13/01	AC	AC unit not putting out cold air. This AC unit is in the N/S branch head's office located on Mezzanine Above shop 6.2.93662 (machine shop).
106719	4/13/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
106720	4/13/01	AC	Check operation of chillers and record readings each day. 6.3.658
106721	4/13/01	AC	Check operation of chillers each shift and record readings. 6.3.658
106722	4/13/01	AC	Check operation of chillers each shift and record readings. 6.3.658
106723	4/13/01	AC	Check operation of chillers each shift and record readings. 6.3.658
106737	4/16/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
106748	4/16/01	AC	Check AC unit over old action center in bldg 133
106757	4/16/01	AC	T2 on the #1 T64 manual test stand will not maintain temp no cold work stop
106767	4/16/01	AC	Repair fuel leak on heating system
106794	4/16/01	AC	Clean room temp is 78 degrees and humidity is 50%. This out of limits for the clean room
106826	4/17/01	Vents	Air vent is not working properly in welding shop.
106837	4/17/01	AC	Need new air filters. Please ensure quality filters are used. No el-cheapos
106842	4/17/01	AC	Air temp too cold in shop 96332/ Mezzanine E
106843	4/17/01	Vents	Vents in shop area needs cleaning.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
106878	4/17/01	AC	Need instruction on how to turn AC unit off in ramp bldg, turned in call ticket last week to turn AC on, works great but people are turning blue today.
106880	4/17/01	AC	Attn. Ellis Electric may need to check AC it got cold out side and AC is running wide open about to freeze
106881	4/17/01	AC	Temp/hum too high - clean room work stop - repair - ASAP.
106905	4/17/01	Vents	Ventilation in the new hanger is operating with excessive positive pressure. This almost caused injury to an employee trying to exit from the old hanger.
106908	4/17/01	AC	Heaters blowing cold air (main steam relief valve, relieves as soon as steam valve is cracked open). This was reported a couple of months ago.
106911	4/17/01	AC	Heaters blowing cold air (main steam relief valve, relieves as soon as steam valve is cracked open). This was reported a couple of months ago.
106917	4/18/01	AC	Fan belt needs to be replaced on the heater & air system.
106919	4/18/01	AC	AC vent is making loud squeaky noise...
106928	4/18/01	AC	Humidity in clean room too high 68 vs. 40 +/- 10.
106949	4/18/01	AC	It is cold in the bldg we need the heater turned on.
106974	4/18/01	AC	Repair unit door hinges and broken mounts. Discrepancy found while performing PM on link #V732915
106983	4/18/01	Vents	Please repair (4) ea shop tools for shop 96556: support adapter s3s1818000, hoisting adapter s3s18167000, lifting extractor 18169000, #3 brng puller.
106985	4/18/01	AC	The AV-8B trainer program office is colder than outside. We are all working in jackets.
107021	4/18/01	Vents	Assist grease vent bearings for varsol spray booth in shop 94105, vent # 137-36. Send to 65100.
107043	4/19/01	AC	No heat
107046	4/19/01	AC	Humidity in clean room too high and fluctuating
107063	4/19/01	AC	Temperature in new 960 conference room, bldg 133 is cold and they are trying to use small portable heaters. These heaters are tripping circuit breakers. Please check electrical and HVAC settings.
107106	4/19/01	AC	No AC
107115	4/19/01	AC	No AC
107129	4/19/01	AC	Check Liebert AC unit in clean room temp out of limits.
107144	4/19/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
107145	4/19/01	AC	Check operation of chillers second shift and record readings each day. 6.3.658
107146	4/19/01	AC	Check operation of chillers second shift and record readings each day. 6.3.658
107147	4/19/01	AC	Check operation of chillers second shift and record readings each day. 6.3.658
107148	4/19/01	AC	Check operation of chillers second shift and record readings each day. 6.3.658

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
107160	4/20/01	AC	Perform work per the attached for the week of 4/23/01
107161	4/20/01	AC	Perform work per the attached for the week of 4/23/01
107163	4/20/01	AC	Perform work per the attached for the week of 4/23/01
107165	4/20/01	AC	Perform work per the attached for the week of 4/23/01
107166	4/20/01	AC	Perform work per the attached for the week of 4/23/01
107203	4/20/01	AC	Temperature too high in clean room. Calibration lab, 94203. Work stoppage
107227	4/20/01	AC	AC will not turn on.
107233	4/20/01	AC	AC making a chirping, very annoying noise.
107241	4/23/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
107242	4/23/01	AC	Very, very hot in shop. Please turn on some AC.
107248	4/23/01	AC	The stairway to Mezzanine J is very hot, could someone please check this out.
107268	4/23/01	AC	Important: software support (secured) lab (ssa) has AC problems. The humidity alarm keeps doing off. Needs to be checked and repaired as soon as possible.
107275	4/23/01	AC	Mezzanine G last room on left data base office AC not working well
107284	4/23/01	AC	Cannot achieve -15 degrees T2 temperature on T64 manual test stand # 1. Work stoppage
107296	4/23/01	AC	AC out in eatery
107312	4/23/01	AC	T2 temp control is not working. Unit will not go cold.
107331	4/23/01	AC	AC on heat alarm light is on
107343	4/23/01	AC	Check AC units in shop. AC not working. Hot in all area.
107346	4/23/01	AC	The middle of the CPU room is at 80 degrees. The dehumidification light keeps coming on the front AC. The area near the operators desk temp is 79 degrees. Need AC personnel to check it out.
107352	4/24/01	AC	AC is blowing full cold in SE wing lower level. Having trouble regulating AC to provide equitable distribution between Cass lab & Cass office spaces.
107364	4/24/01	AC	AC is making a hissing noise and is not cooling properly.
107374	4/24/01	AC	Igv stand needs charging. Work stop
107377	4/24/01	AC	It has been 60 degrees in the workspace for a week. It never warms up.
107381	4/24/01	AC	T64 # 2 manual test stand has a chill water leak. Work stoppage
107384	4/24/01	AC	Our AC is leaking water. Someone attempted to fix a couple of weeks ago. Please try again.
107390	4/24/01	Vents	Replace motor on vent 4032-15. Material \$181.20. Labor \$11280. Discrepancy was discovered while performing PM. Work has already been done.
107391	4/24/01	AC	Modon heater is pumping out heat and won't shut off.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
107394	4/24/01	AC	Modon heater is pumping out heat and won't shut off.
107395	4/24/01	AC	Temperature is too high in the mixing room.
107396	4/24/01	AC	Help!!! We have no AC at all. It's hot in here. The fans are barely stirring the air. Please come check.
107397	4/24/01	AC	AC inoperable in office area. Very hot and stuffy in offices located next to hanger deck.
107409	4/24/01	AC	It is too hot in our office and we have no control over the thermostat.
107420	4/24/01	AC	A/C not cooling properly
107424	4/24/01	AC	AC stop working in CH-46 pool, urgent request due to moisture on RFI
107428	4/24/01	AC	AC system drain water in equipment room, repair before water shorts out electrical system
107460	4/24/01	AC	Only half of unit functioning. Need repaired. Work stoppage.
107466	4/25/01	AC	AC leaking in clean room. Needs repair ASAP. Work stop - safety hazard
107470	4/25/01	AC	Investigate condensate problem and repair if within monetary limit.
107487	4/25/01	AC	Disconnect small polycold chiller located behind bldg 133; disconnect pigtail from box; remove 2 overhead airlines. Store chiller per instructions
107488	4/25/01	AC	Refrigerant leak on the expansion valves in the 100-ton AC possible warranty tri-plex. ASAP thanks
107490	4/25/01	AC	Check out water leak in the bearing shop. Work stoppage
107508	4/25/01	AC	Perform task as per task 107288 attn: tri-plex provide cost estimate for approval before. Contractor shall schedule work before starting .
107562	4/25/01	AC	Belt on purge air system has slipped off
107565	4/25/01	AC	Various machines throughout the shop need the AC filter change.
107567	4/25/01	Vents	Plant account vents 133-222 & 133-223 per the attached.
107570	4/25/01	AC	Repair problem on air dryer on wotan machine.
107672	4/26/01	Vents	Remount disconnect on vent 133-5. Discrepancy found during PM on link #V750543.
107698	4/26/01	AC	Please provide information on the 7.5-ton Trane chilled water system installed on BPA 99-a-5588 call no. 1024 so the unit can be plant accounted. Please provide maintenance manual for the unit.
107707	4/26/01	AC	Heater leaking in steel repair area (across from weld shop)
107743	4/26/01	AC	Check oil levels in Trane compressors and record readings each day 6.3.658
107743	4/26/01	AC	Check oil levels in Trane compressors and record readings each day 6.3.658
107744	4/26/01	AC	Check operation of chillers, take readings, and record each day. 6.3.658
107745	4/26/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
107746	4/26/01	AC	Check operation of chillers, take readings and record each day. 6.3.658

Ticket Number	Date	Problem Type	Description
107747	4/26/01	AC	Check operation of chillers, take readings and record each day. 6.3.658
107760	4/27/01	AC	Replace cores and circulator pumps. Discrepancy found while performing PMs on link #'s v732884 thru v732886.
107761	4/27/01	AC	No chill water, test stands running hot/work stop
107762	4/27/01	AC	Extreme pressure in clean room causing doors to be difficult to open
107777	4/27/01	AC	No chill water in the RCA room.
107783	4/27/01	AC	No heat or AC in office. Needs ventilation
107784	4/27/01	AC	Perform work per the attached.
107785	4/27/01	AC	Perform work per the attached.
107786	4/27/01	AC	Perform work per the attached.
107803	4/27/01	AC	1. Message on thermostat says filter needs cleaning. 2. Areas are still either too hot or too cold.
107856	4/30/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
107857	4/30/01	AC	There is no heat in cans I thank we are out of gas
107858	4/30/01	AC	Heater has flooded his area - just fixed about 3 weeks ago
107868	4/30/01	AC	Troubleshoot control problem with Mezzanine G computer room HVAC units. All three are running simultaneously. (both Lieberts and the Trane rooftop unit.)
107869	4/30/01	AC	Test stand too hot/work stop
107896	4/30/01	Vents	Vents in the office area need cleaning badly. No air coming out. Help
107901	4/30/01	AC	ASE test stands cannot maintain 75 degrees/work stop
107904	4/30/01	Vents	Manufacture and install exhaust damper for exhaust fan #4 on roof of bldg
107907	4/30/01	AC	AC feeding into the office area is not working. It is getting rather warm in here. Thanks
107908	4/30/01	AC	Test stand running too hot/work stop
107926	4/30/01	AC	Temperature too high in clean room - need someone to repair.
107954	4/30/01	AC	Loud knocking noises are coming from air handler in maintenance room upstairs in bldg 200.
107963	4/30/01	AC	AC broken will not work; work stoppage.
107992	5/1/01	AC	Excessive pressure in clean room making door impossible to open/safety issue
107996	5/1/01	AC	Pressure inside fuel control clean room is extremely high and creating a safety hazard.
107999	5/1/01	AC	AC system will not come on.
108023	5/1/01	Vents	Fan on spray paint booth is making noise. Possible bearing failure. Work stoppage priority 1 this is a vent stack
108079	5/1/01	AC	Check AC in bldg 423. Hot in the area. Thanks.



Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
108088	5/1/01	Vents	Louver on exhaust fan doesn't open when turned on. Located in pneumatic cleaning shop.
108120	5/2/01	AC	Need vent deflector installed under a /C vent
108130	5/2/01	AC	AC in 143 not working very hot
108135	5/2/01	AC	Repair refrigerant leak on the 30-ton compressor to the cable shop attn: tri-plex
108137	5/2/01	AC	Install heating coil in roof top air handler for eatery
108141	5/2/01	AC	Install water valve on T64 test stand
108142	5/2/01	AC	Install heat exchanger and repair chiller
108143	5/2/01	Vents	Exhaust fan in bldg 4588 is not working.
108145	5/2/01	AC	Test stands running hot
108147	5/2/01	AC	Relative humidity in clean room is 59% and rising/max 40%+/- 10
108162	5/2/01	AC	AC and ducting need cleaning- vents are black and filter was dirty before and after it inside.
108178	5/2/01	AC	Service window AC unit as necessary (6.3.658)
108191	5/3/01	AC	Prop. Shop AC inoperable in test and P-3 area.
108203	5/3/01	AC	The AC for the 96300 training room / office in bldg 133 does not seem to be cooling properly. Request it be checked and/or fixed. Thanks.
108214	5/3/01	AC	No AC coming through vents. Located downstairs, across from break room, in middle of shop, room 530.
108241	5/3/01	Vents	Need a diverter made for AC vent above my desk. Was asked to direct this to 655 being they have made these in the past.
108257	5/3/01	AC	AC in P-3 rubber room and in E-2 rubber room and I/E mod. Room is out these is temperature control rooms we are at a work stoppage help ASAP thanks.
108258	5/3/01	AC	Test stand 3012 the inlet fuel temp to high: work stoppage
108271	5/3/01	AC	AC in P-3 rubber room have went back down we are back in a work stoppage please help thanks.
108274	5/3/01	AC	AC needs PM. This is a window unit in the QAs office next to the rotor blade shop office (6.2.94304).
108362	5/4/01	AC	Very hot in offices! AC inoperable in this area. Need help ASAP!
108402	5/4/01	AC	Check oil level in Trane compressors and record readings each shift. (6.3.658)
108403	5/4/01	AC	Check operation of chillers, take and record readings each shift. 6.3.658
108404	5/4/01	AC	Check operation of chillers, take and record readings each shift. 6.3.658
108405	5/4/01	AC	Check operation of chillers, take and record readings each shift. 6.3.658
108406	5/4/01	AC	Check operation of chillers, take and record readings each shift. 6.3.658
108417	5/4/01	AC	Located behind guard station have a pipe from chill water valve is busted.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
108419	5/5/01	AC	Chill water inoperable on dowty test stands in accessories test area. Work stoppage on all FMU test stands.
108425	5/7/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
108426	5/7/01	Vents	Perform bi-annual PM per the attached PM card. Record the amount of time required to perform the PM on the card. Link # v775345
108427	5/7/01	AC	Perform work per the attached.
108428	5/7/01	AC	Perform work per the attached sheet
108429	5/7/01	AC	Perform work per the attached sheet.
108444	5/7/01	AC	Change expansion valve on T64 test stand #1
108445	5/7/01	AC	Leak coming in from the overhead in ASE pump room.
108450	5/7/01	Vents	Need a diverter made for AC vent above my desk. Was asked to direct this to 655 being they have made these in the past.
108453	5/7/01	AC	AC needs PM. This is a window unit in the QAs office next to the rotor blade shop office (6.2.94304).
108454	5/7/01	AC	AC needs PM. This is a window unit in the QAs office next to the rotor blade shop office (6.2.94304).
108460	5/7/01	AC	Heater running full blast in men's head. Very, very, unbearably hot, over 90degrees in there. Need help ASAP!
108464	5/7/01	AC	Men's bathroom M-113 is approximately 100 degrees. Needs attention immediately!!!
108476	5/7/01	AC	Temp has dropped below required limits in the calibration lab on Mezzanine F. Calibration work stoppage repair ASAP.
108479	5/7/01	AC	Repair water cut off to humidifier, txv iced up, belts loose and replace refrigerant. Discrepancy found while performing PM on link #V764233.
108481	5/7/01	AC	No AC, climate control room
108538	5/7/01	AC	Attention 652 inspect compressor for the CNC AC on the robotic shot peen machine
108541	5/7/01	Vents	Diffuser needs to be put back into place.
108579	5/8/01	AC	Heater blowing desert heat again in men's head. Over 90 degrees hot in there. Help!
108580	5/8/01	AC	Men's bathroom M-113 is 100 degrees again this morning. If you need to lose some weight, it's the perfect sauna! Needs prompt attention! Second request!
108607	5/8/01	AC	H46 SBU AC filters are dirty and causing problem breathing
108608	5/8/01	AC	AC systems down in RCA room
108630	5/8/01	AC	Repair leaking pipes and/or valves in 500-ton equipment room, bldg 133
108641	5/8/01	AC	Too hot in clean room
108657	5/8/01	AC	AC inoperable in NC maintenance shop
108662	5/8/01	AC	Change out compressor parts under warranty
108666	5/8/01	AC	AC needs PM. This is a window unit in the QAs office next to the rotor blade shop office (6.2.94304).

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
108667	5/8/01	AC	AC inoperable in NC maintenance shop
108676	5/8/01	AC	Prop. Shop air handler, in paint room leaking water.
108692	5/8/01	AC	Hot in ASKARS
108697	5/8/01	AC	Need to check AC unit. Airflow to strong for the thermal room. Cannot control. POC on night shift.
108783	5/9/01	AC	Repair or replace window unit in office. Air is not cold.
108786	5/9/01	AC	AC is not working in mixroom work stoppage
108792	5/9/01	AC	Repair AC in the Cal lab.
108815	5/9/01	AC	Check AC condition in bonding room. Freezing in area. Thanks.
108821	5/9/01	AC	Install new blower motor in window unit. (6.3.658)
108838	5/10/01	Vents	Troubleshoot electrical problem on F-2 (mixing room general exhaust fan). Fan should be interconnected with F-7 (new mixing booth exhaust fan) and the mixing room makeup air unit. The intent is for all 3 to run, all the time.
108842	5/10/01	AC	Please check and repair AC in thermal image room (old bonding room) located by stairway going up to payroll. Please ensure repairman gets further instructions.
108946	5/10/01	AC	AC seems to be freezing up, temperature constantly rising
108958	5/10/01	AC	AC in shop making whistling noise
108963	5/10/01	AC	Liebert AC unit in instrument side of shop making a squealing noise.
108970	5/10/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
108971	5/10/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
108972	5/10/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
108973	5/10/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
108974	5/10/01	AC	Check operation of chillers second shift. Take and record readings each day. 6.3.658
108985	5/11/01	Vents	Provide FSC contract to PM ventilation as per instruction send this to 655 thanks
108986	5/11/01	Vents	Provide FSC contract to PM ventilation as per instruction send this to 655 thanks
108996	5/11/01	AC	It's 80 degrees in here this morning. Please turn the AC. On!!!
109008	5/11/01	AC	Provide contract to retro-fit the last remaining test stand do not start unless approved from 65500 (send to 655)
109081	5/11/01	AC	Could we please have some cool air in our work area? Production control area next door to us has cool air but we don't. Thanks.
109097	5/13/01	AC	Cannot achieve -15 degrees T2 temperature on T64 manual test stand number one in accessories test. Work stoppage
109098	5/14/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
109116	5/14/01	AC	T2 won't go hot/work stop

Ticket Number	Date	Problem Type	Description
109119	5/14/01	Vents	Vent fan in restroom bldg 423 laboratory area is inoperable.
109123	5/14/01	AC	CRU #1 in computer lab room 107 has an air flow loss alarm. Suspect blower drive belt broken. This will lead to a work stoppage.
109135	5/14/01	AC	Belt on AC squealing. (AC located in instrument area)
109158	5/14/01	AC	CRU #1 in computer lab room 107 has an air flow loss alarm. Suspect blower drive belt broken. This will lead to a work stoppage.
109159	5/14/01	AC	CRU #1 in computer lab room 107 has an air flow loss alarm. Suspect blower drive belt broken. This will lead to a work stoppage.
109160	5/14/01	AC	Belt on AC squealing. (AC located in instrument area)
109175	5/14/01	AC	AC not working in shop 94405, 11300
109198	5/14/01	AC	AC in 94403 section of the new area of pneumatic is not putting out any cold air
109216	5/15/01	AC	Very hot in shop. Please turn on some AC.
109225	5/15/01	AC	The AC unit in bldg 129 is kicking the breaker.
109239	5/15/01	AC	Controlled environment not controlled. P-3 "rubber room" AC is non-operational. Heat is on. Room is supposed to be maintained at a constant temperature of between 68-72 degrees F.
109254	5/15/01	AC	Services all the small AC in the bldg attn: tri-plex
109260	5/15/01	AC	Very hot in shop. Please turn on some AC.
109261	5/15/01	AC	Very hot in shop. Please turn on some AC.
109269	5/15/01	AC	Still too hot in 94405, 11300, & 94403 new test cell area
109294	5/15/01	AC	Perform quarterly PM per the attached PM card. Record the amount of time required to perform PM on the card. Link #V775370
109316	5/15/01	AC	Lost all chill water in hazardous test area. Test stands over heating. Work stoppage
109356	5/16/01	AC	AC unit in the rear of bldg 133 is blowing warm air.
109359	5/16/01	AC	AC unit is not cooling again in the NC area. A contractor worked on this unit last week.
109378	5/16/01	AC	Request the heat be turned off in this bldg there is a meeting in the conference room and the heat is stifling.
109381	5/16/01	AC	Heat is on in the 4470 conference room. Meeting taking place now and the heat is on. Request someone turn it off and get AC working again.
109383	5/16/01	AC	AC for final assy and E-2 rubber room is not working. Blowing hot air. Please repair ASAP! Thanks.
109393	5/16/01	AC	Humidifier alarm on unit at north end of computer room
109442	5/16/01	AC	Warm air coming out of AC vent in SIS stacker area.
109457	5/17/01	AC	T2 system will not come on/work stop
109463	5/17/01	AC	AC at post 6 is broke.
109503	5/17/01	AC	T-58 mech #5 test stand unable to set T-2 cold position to minus 25: work stoppage
109516	5/17/01	AC	AC needs checked out at Mezzanine C

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
109526	5/17/01	AC	Assist engineering in trouble shooting AC for front office area bldg 137
109533	5/17/01	AC	Low pressure switch popped on T2 system/work stop
109541	5/17/01	AC	Increase temperature in blade shop bonding room. Temp now is at 63 degrees and 57% humidity. Temperature needs to be at least 65 degrees.
109554	5/17/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
109555	5/17/01	AC	Check operation of chillers. Take and record readings each shift. 6.3.658
109556	5/17/01	AC	Check operation of chillers. Take and record readings each shift. 6.3.658
109557	5/17/01	AC	Check operation of chillers. Take and record readings each shift. 6.3.658
109558	5/17/01	AC	Check operation of chillers. Take and record readings each shift. 6.3.658
109571	5/18/01	AC	Temperature too low in optical room.
109573	5/18/01	AC	AC broke CH-46 hangar, back on flight line end, central air unit
109576	5/18/01	AC	AC at post 6 is broke, located at gate 13, bldg 4224
109578	5/18/01	AC	Low pressure switch popped on T2 system/work stop
109599	5/18/01	AC	Excessive heat and humidity.
109622	5/18/01	AC	Controlled environment not controlled P-3 rubber room AC non-operational. Bad fan motor and low on gas
109627	5/18/01	AC	AC unit just installed - keeps going off. (this was discussed 5/18/01)
109640	5/18/01	AC	AC not working - Liebert units on Mezzanine G that feeds computer room
109643	5/18/01	AC	AC will not turn on and it is over 80 degrees and it is very humid.
109645	5/18/01	AC	The ice machine in the back aisle by heat treat seems to be running but has not made any ice. What ice is in the hopper is melting. POC at the trumpf punch machine across from the eatery thanks
109646	5/18/01	AC	Water pouring out of unit in the overhead in 96331 annex in bldg 133. The water is leaking on the office.
109647	5/18/01	AC	T-58 mech test stand the T-2 won't go down to -25> work stoppage:
109660	5/20/01	AC	AC power itself off/check the unit to the right as you walk in the door. It seems to be either tripping a breaker or just shutting off early
109661	5/21/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
109662	5/21/01	AC	AC in main electronic security system control room has quit working. Essential service. Located next to bldg 137 main lobby. Contract me for entry.
109663	5/21/01	AC	Hp/AC not working right in bldg 427. Possible wiring problem.
109665	5/21/01	AC	No AC this morning, temperature is 85 and rising.
109667	5/21/01	AC	AC is not working in the 960 SBU.
109669	5/21/01	AC	AC in 960 SBU office, Mezzanine A, bldg 133 inoperable. Please address ASAP.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
109675	5/21/01	AC	Old rubber shop area, air is too cold, please turn it up.
109678	5/21/01	AC	Old rubber room area, air is too cold, please turn up.
109681	5/21/01	AC	Urgent request to have someone from the AC shop come over and look at the AC for the Sermetel room in the paint area. This is a work stoppage request.
109683	5/21/01	AC	Six ACs on the roof above the machine shop are not working, shop is over 80 degrees. Two of these air units are above ramp building, four over the 93562 machine shop. On roof no water is dripping from units and compressors not working.
109687	5/21/01	AC	Very hot in shop again. Please turn on some AC, fix problem with AC.
109689	5/21/01	AC	Cannot achieve -15 degrees T2 temperature on T64 manual test stand # 1. Work stoppage
109693	5/21/01	AC	Ice machine not working, will not make ice, machine located on heat treat aisle. Please fix ASAP.
109699	5/21/01	AC	Need new air filters for AC
109702	5/21/01	AC	No chill water, test stands running too hot
109709	5/21/01	AC	Hard anodize T-033 is not cooling to the specified temp this is a work stoppage. Thanks
109714	5/21/01	AC	Ice machine next to the instrument shop is inoperable
109719	5/21/01	AC	Very hot in shop again. Please turn on some AC, fix problem with AC.
109720	5/21/01	AC	Not functioning properly/above 80 degrees and the computers are affected by temperature
109724	5/21/01	AC	AC is down. Requesting help as soon as possible
109726	5/21/01	AC	The backup AC drain is clogged and dropping moisture on the steps leading to the central tool room. This is an unsafe condition. The main air unit is out and the backup must be used to keep equip cool.
109732	5/21/01	AC	Upstairs AC not blowing cool air.
109739	5/21/01	AC	Humidity in clean room too high 65% vs. 40% +/- 10/
109741	5/21/01	AC	AC unit on top of roof has leaked and saturated the roof and the ceiling is leaking. H2O is leaking around electrical items and computers. Safety hazard
109744	5/21/01	Vents	Change adjustable two-groove pulley, 1 7/8" shaft. Discrepancy found while performing PM on link #V764220
109748	5/21/01	AC	Repair AC for back computer room, icing up
109767	5/21/01	AC	Ice maker and water fountain in aisle way by heat treat area of shop not working.
109779	5/21/01	AC	Repair AC controls at bldg 1665 ref. Ticket 109643
109786	5/21/01	AC	AC not working in the mixing room. It is a work stoppage.
109805	5/21/01	AC	AC in bldg 4033 has not been working all day. Repair was called in this morning; however, repairman was out working on an AC to the rear of 4033 not the one for this bldg
109809	5/21/01	AC	Temperature too low, humidity too high in optical room.

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
109814	5/21/01	AC	Need the AC check in hazardous test area. Blowing hot air:
109828	5/22/01	AC	Thermostat completely off, cooling unit not working. Located in the ASKARS bldg, kitting and NIF store material side
109834	5/22/01	AC	No AC in accessories test area/
109843	5/22/01	AC	Warm and "muggy" in shop. Please check AC.
109847	5/22/01	AC	Air unit for downstairs racking area is not cooling. Appears fan is not blowing correctly. Thanks
109849	5/22/01	AC	Hf furnace room is very hot, please help.
109850	5/22/01	AC	Repair unit causing leak if the overhead of the front office area
109856	5/22/01	AC	Unit in exposure room will not come on.
109876	5/22/01	AC	The AC in bldg 133, training office, does not seem to be working properly. Please have it checked. It does get pretty hot/stuffy when giving classes. Thanks.
109903	5/22/01	AC	Air handler in penthouse is not running. Could you please check, it is over F402 shop. Thank you!
109909	5/22/01	AC	Upstairs AC not working properly. Blowing warm air
109924	5/22/01	AC	It's summer again and the AC will not keep the bldg cool, especially when classes are in session.
109927	5/22/01	AC	Humidity in clean room at 75%.
109937	5/22/01	AC	AC in ISPAC lab is malfunctioning. Airflow restricted, hot, humid air is coming out and all the status lights are out. The equipment can be effected by this
109945	5/22/01	AC	Parts washer is not heating up work stoppage
109958	5/22/01	AC	Unit will not cool to right temperature for office.
109965	5/23/01	AC	AC is not operable. Temp is over 95 degrees in this office. Help! Training classes have to be cancelled due to heat in area. Work stoppage.
109968	5/23/01	AC	AC in shop not working again. Please fix.
109970	5/23/01	AC	AC is not working
109971	5/23/01	AC	Condensation leaking out of test stand/
109972	5/23/01	AC	Condensation leaking out of test stand/
109976	5/23/01	AC	Ac1 blowing out hot air. Shop is so hot its hard to breath. Thanks!!
109978	5/23/01	AC	Air system within the metallurgical branch has shut off.
109979	5/23/01	AC	AC blowing hot air again, third request, every day this week when we come in it's broken. It is miserable working in a shop with no windows with no AC. Someone looked at it yesterday, it started to cool, today it is extremely hot again
109989	5/23/01	AC	Extreme heat condition in this area! Need some cool!
109993	5/23/01	AC	No AC in accessories test area/
110000	5/23/01	AC	No AC in shop area 96332

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
110001	5/23/01	AC	AC unit on the "old" (SIS) side is not operating. Hot
110008	5/23/01	AC	AC in break room not putting out cold air
110012	5/23/01	AC	Heater on in restroom in downstairs in men's head starting too get hot
110021	5/23/01	AC	T2 system on T64 # 1 manual test stand will not achieve 145 degrees. Work stoppage
110024	5/23/01	AC	Conference room in bldg 4470 continues to be unbearably hot. Ticket # 109378 refers.
110052	5/23/01	AC	Repair AC unit
110058	5/23/01	AC	Temp has dropped below the required limits for calibration on Mezzanine F, repair as soon as possible, calibration work stoppage exist. This is a repeat problem with the AC which needs to be corrected.
110069	5/23/01	AC	Clean and PM all vav boxes on AC unit in the front of the bldg replace bad hot water valve
110072	5/23/01	AC	Perform repair guidelines as described in the engineering handout on the unit for co's office
110078	5/23/01	AC	Hygrothermo-graph digital reading for temp and humidity differ from chart reading.
110079	5/23/01	AC	Replace valve and install air dryer
110080	5/23/01	AC	AC is not working properly
110091	5/23/01	AC	T2 running too hot/work stop/
110096	5/23/01	AC	In code 6.2.960 division director's support office, air vent over desk has no ductwork connect to it. Would you provide the appropriate ductwork to this vent.
110109	5/24/01	AC	Hygrothermo-graph digital reading for temp and humidity differ from chart reading.
110126	5/24/01	AC	Temperature too low in optical room
110154	5/24/01	AC	Retro-fit test stand T-64 as per instructions send to 655
110181	5/24/01	AC	T2 going too hot/work stop/
110183	5/24/01	AC	T2 system inoperable on T64 # 1 manual fuel control test stand. Work stoppage
110184	5/24/01	Vents	Need to have a vent reflector installed over desk.
110191	5/24/01	AC	Replace 75 psi valve on chill water
110195	5/24/01	AC	Replace the bad AC compressor in ASKARS
110200	5/24/01	AC	Change AC filters 20" x 20" x 2" 10 each.
110223	5/24/01	AC	Check oil level in Trane compressors and record readings each day. 6.3.658
110224	5/24/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
110225	5/24/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
110226	5/24/01	AC	Check operation of chillers, take and record readings each day. 6.3.658



Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
110227	5/24/01	AC	Check operation of chillers, take and record readings each day. 6.3.658
110259	5/25/01	AC	Window unit AC does not work.
110268	5/25/01	AC	Air in metal spray room
110273	5/25/01	AC	AC blowing hot air in the AEP area.
110278	5/25/01	AC	AC in the calibration lab has quit working, work stoppage this unit was worked on recently, see ticket #110058.
110283	5/25/01	AC	T2 system inoperable on T64 # 2 manual fuel control test stand. Work stoppage
110286	5/25/01	AC	Need to have the probe look at on the vapor degreaser.
110297	5/25/01	AC	Repair controls in the eatery AC 66 degrees in the room
110308	5/28/01	AC	Check gas levels in propane tanks for cans and bldgs check small gas cylinder.
110309	5/29/01	AC	AC not working properly.
110310	5/29/01	AC	Work stoppage!!!!!! Bonding room is down. No AC
110311	5/29/01	AC	Mezzanine F, way too cold, climate controlled area, calibration work stoppage
110314	5/29/01	AC	This bldg is not being cooled per instructions. A ticket was turned in last week (110080) to warm things up a bit. Aware of the problem. Can you tell us why we cannot get the AC to work properly? It is still too cool.
110330	5/29/01	AC	Repair
110333	5/29/01	AC	Condensing fan motor is not working. Circuit breaker trips when unit is engaged. Check oil leak in top compressor head. Tri-plex has been working on this unit
110352	5/29/01	AC	Located on Mezzanine E, bldg 137, NC programming shop - computer room AC inoperable - blowing hot air only - Liebert challenger model 3000
110356	5/29/01	AC	The lab, which should be 75 F and 50% RH, is currently 58 F and 80% RH.
110373	5/29/01	AC	Repair
110374	5/29/01	AC	Repair - temp too low - work stop climate controlled area, clean room
110379	5/29/01	AC	No chilled water to hydraulic test stands! Work stoppage!
110380	5/29/01	AC	Tank-033 hard anodize is not cooling down to 40 degrees. Work stoppage. Thanks
110395	5/29/01	AC	Chill water control valve not working
110398	5/29/01	AC	To have yearly PM done on air handler.
110399	5/29/01	AC	Test stand leaking chill water
110402	5/29/01	AC	Attn: contractors condensation pump over ASE 1 and 3 is clogged or in need of repair. Work stop
110405	5/29/01	AC	Condensation pump over ASE 1 and 3 not working

Industrial Maintenance Services  
HVAC&R Repair Work Orders (continued)

N00421-03-R-0060

Ticket Number	Date	Problem Type	Description
110406	5/29/01	AC	Both T64 manual fuel control test stands are inoperable for electrical power and according to electrical maintenance; chill water is causing the problem. Work stoppage
110415	5/29/01	AC	AC is too cold-climate controlled area, materials engineering lab
110418	5/29/01	AC	Check and repair chiller, cooling tower in the bldg 133 as per instruction
110423	5/29/01	AC	Repair/replace controls on the AC for the lobby in 133. Attn: tri-plex
110424	5/29/01	AC	AC unit is leaking badly. Ceiling tiles are falling down from the moisture and there is two trashcans catching the water. They are now overflowing. Immediate attention please.
110448	5/29/01	AC	Employees continue to complain of being very hot and not enough cooling coming from AC. AC men have been here and made some repairs, but things have not gotten better/or cooler, and today it's cool outside.
110463	5/30/01	AC	Water is leaking from ceiling. Deck is soaked. Suspect AC system. Please stop leak. Safety hazard.
110468	5/30/01	AC	T2 inoperable/work stop
110469	5/30/01	AC	AC drain leaking on stairs on high bay area paint class safety hazard.
110473	5/30/01	AC	It's way to cold in the photo lab. It hasn't been over 60 degrees in two days.
110478	5/30/01	AC	Manufacture drip pans for bearing shop bldg 133.
110480	5/30/01	AC	Prop shop AC in E-2 bonding room inoperable.
110492	5/30/01	AC	Repair leak from the AC over the drop ceiling notify POC when complete. Repair steam modulating valve
110500	5/30/01	AC	Would like to have the temperature adjusted or be balanced out throughout the area. As there is only one control unit for this area and our area is to cool.
110509	5/30/01	AC	Employees continue to complain of being very hot and not enough cooling coming from AC. AC men have been here and made some repairs, but things have not gotten better or cooler, and today it's cool outside.
110511	5/30/01	AC	Employees continue to complain of being very hot and not enough cool air coming from AC. AC men have been here and made some repairs, but things have not gotten better or cooler, and today it's cool out.
110517	5/30/01	AC	Compressor in unit in exposure room will not come on. AC #51
110526	5/30/01	AC	Repair supply air duct and register in 610 conference room.
110539	5/30/01	AC	Repair AC in the break room
110554	5/30/01	AC	AC is not working, it's 80 degrees and climbing
110570	5/30/01	AC	Temp will not go below 0 degrees on the T-2: work stoppage:
110571	5/30/01	AC	The chillers are down for our anodize lines. Thanks
110595	5/31/01	AC	AC appears to be turning off at end of shift. The bldg is humid and hot when employees report at start of first shift. Because of assembly procedures it is important that the bldg stay at a constant temperature and reasonable humidity level